

**SOIL/SITE EVALUATION**  
**for ON-SITE WASTEWATER SYSTEM**

Owner:                      Applicant:  
 Address:                      Date Evaluated: **2-21-13**  
 Proposed Facility: **SFD**                      Design Flow (.1949): **3 cgd**                      Property Size:  
 Location of Site:                      Property Recorded:  
 Water Supply:                       Public  Individual  Well                       Spring                       Other  
 Evaluation Method:  Auger Boring                       Pit                       Cut  
 Type of Wastewater:                       Sewage                       Industrial Process                       Mixed

P R O F I L E #	.1940 Landscape Position/ Slope %	Horizon Depth (In.)	SOIL MORPHOLOGY .1941		OTHER PROFILE FACTORS				Profile Class & LTAR
			.1941 Structure/ Texture	.1941 Consistence Mineralogy	.1942 Soil Wetness/ Color	.1943 Soil Depth (IN.)	.1956 Sapro Class	.1944 Restr Horiz	
1	L-5 1/2% -1052	0-30	SL	MGCLNSP					
		30-42	SL-clay	CL 1 5/8 S.P.	40" 7.5-12 3.1				.4
2	L-6 7/8%	0-24	SL	MGCLNSP					
		24-42	SL-clay	CL 1 5/8 S.P.	36" 7.5-12 3.1				.4
3	L-7 1/2%	0-22	SL	MGCLNSP					
		22-40	SL-clay	CL 1 5/8 S.P.	34-36" 7.5-12 3.1				.4
4	L-7 1/6%	0-12	SL	MGCLNSP					
		12-36	Sedgy	CL 1 5/8 S.P.	24" 7.5-12 3.1				.25

Description	Initial System	Repair System	Other Factors (.1946): Site Classification (.1948): <b>P3</b> Evaluated By: <b>[Signature]</b> Others Present:
Available Space (.1945)			
System Type(s)	<b>25 1/2</b>	<b>25 1/2</b>	
Site LTAR	<b>4</b>	<b>7</b>	