

**SOIL/SITE EVALUATION  
 for ON-SITE WASTEWATER SYSTEM**

Owner:                      Applicant:  
 Address:                    Date Evaluated: 4/2/13  
 Proposed Facility: 4 bedrooms      Design Flow (.1949): 480 gpd      Property Size:  
 Location of Site:                      Property Recorded:  
 Water Supply:                     Public  Individual       Well       Spring       Other  
 Evaluation Method:  Auger Boring       Pit       Cut  
 Type of Wastewater:                     Sewage       Industrial Process       Mixed

P R O F I L E #	.1940 Landscape Position/ Slope %	Horizon Depth (In.)	SOIL MORPHOLOGY .1941		OTHER PROFILE FACTORS				Profile Class & LTAR
			.1941 Structure/ Texture	.1941 Consistence Mineralogy	.1942 Soil Wetness/ Color	.1943 Soil Depth (IN.)	.1956 Sapro Class	.1944 Restr Horiz	
1	L 0-2	0-30	G S	VF2 NS/MP					PS .5
		30-40	SB <sup>x</sup> SC <sup>x</sup>	R2 SS/SP					
		40-48	C S	VF2 NS/MP					
2	L 0-2	0-32	G S	VF2 NS/MP					PS .5
		32-48	SB <sup>x</sup> SC <sup>x</sup>	R2 SS/SP					

Description	Initial System	Repair System	Other Factors (.1946): Site Classification (.1948): PS Evaluated By: PS Others Present: /
Available Space (.1945)			
System Type(s)	PUMP	250	
Site LTAR	2	15	

2240 C 15-24