

**SOIL/SITE EVALUATION**  
**for ON-SITE WASTEWATER SYSTEM**

Owner:                      Applicant:  
 Address:                      Date Evaluated: 4/2/13  
 Proposed Facility: 4300-1      Design Flow (.1949): 480 gpd      Property Size:  
 Location of Site:              Property Recorded:  
 Water Supply:               Public  Individual  Well       Spring       Other  
 Evaluation Method:  Auger Boring       Pit       Cut  
 Type of Wastewater:       Sewage       Industrial Process       Mixed

P R O F I L E #	.1940 Landscape Position/ Slope %	Horizon Depth (In.)	SOIL MORPHOLOGY .1941		OTHER PROFILE FACTORS				Profile Class & LTAR
			.1941 Structure/ Texture	.1941 Consistence Mineralogy	.1942 Soil Wetness/ Color	.1943 Soil Depth (IN.)	.1956 Sapro Class	.1944 Restr Horiz	
1	ES 0-2	0-28	C SL	VFN NS/MP					
		28-42	SOKSL	FN SS/S					PS .5
		42 <sup>in</sup>	SOK <sub>6</sub> SL	VFN NS/MP					
2		0-28	G S	VFN NS/MP					
		28-48	SOK <sup>in</sup> SL <sup>in</sup>	FN SS/S					PS .5

Description	Initial System	Repair System	Other Factors (.1946): Site Classification (.1948): Evaluated By: <i>OT</i> Others Present:
Available Space (.1945)	✓	✓	
System Type(s)	PUMP 154		
Site LTAR	1.5	1.5	

4240'