

**SOIL/SITE EVALUATION  
 for ON-SITE WASTEWATER SYSTEM**

Owner:                      Applicant:  
 Address:                      Date Evaluated: 3/13/13  
 Proposed Facility: L BOX                      Design Flow (.1949): 480 gpd  
 Location of Site:                      Property Recorded:                      Property Size:  
 Water Supply:                       Public  Individual  Well                       Spring                       Other  
 Evaluation Method:  Auger Boring                       Pit                       Cut  
 Type of Wastewater:                       Sewage                       Industrial Process                       Mixed

P R O F I L E #	.1940 Landscape Position/ Slope %	Horizon Depth (In.)	SOIL MORPHOLOGY .1941		OTHER PROFILE FACTORS				Profile Class & LTAR
			.1941 Structure/ Texture	.1941 Consistence Mincralogy	.1942 Soil Wetness/ Color	.1943 Soil Depth (IN.)	.1956 Sapro Class	.1944 Restr Horiz	
1	LS 2-5	0-15	G LS						
		15-34	SBX C						PS 14
		34-38	G S						
2		0-28	C		10-127/2 @ 21"				US 2
3		0-12	G SL			G			
		12-30	SBX C		10-127/2 @ 21" (HORIZON CHANGE)				PS 2
		30-42	SBX 1/6 SL			G			
		42-46	SBX SL		10-127/2 @ 21" +		S		

Description	Initial System <input checked="" type="checkbox"/>	Repair System <input checked="" type="checkbox"/>	Other Factors (.1946): PS Site Classification (.1948): PS Evaluated By: ST Others Present: ME
Available Space (.1945)			
System Type(s)	PUMP 25%		
Site LTAR	14	14	