

**SOIL/SITE EVALUATION
 for ON-SITE WASTEWATER SYSTEM**

Owner: Applicant:
 Address: Date Evaluated: 3/15/2017
 Proposed Facility: Design Flow (.1949): Property Size:
 Location of Site: Property Recorded:
 Water Supply: Public Individual Well Spring Other
 Evaluation Method: Auger Boring Pit Cut
 Type of Wastewater: Sewage Industrial Process Mixed

P R O F I L E #	.1940 Landscape Position/ Slope %	Horizon Depth (In.)	SOIL MORPHOLOGY .1941		OTHER PROFILE FACTORS				Profile Class & LTAR
			.1941 Structure/ Texture	.1941 Consistence Mineralogy	.1942 Soil Wetness/ Color	.1943 Soil Depth (IN.)	.1956 Sapro Class	.1944 Restr Horiz	
	6546	0-22	G/KL	VF NSNP					
		22-34	SK/SL	F:SSSP					PS.4
		0-19	G/LS	VF NSNP					
		19-34	SK/SL	F:SSSP					PS.35
		0-38	G/LS	VF NSNP					
		38-42	SK/SL	F:SSSP					PS.5
		0-22	G/SL	VF NSNP					
		22-32	SK/SL	F:SSSP					PS.3

Description	Initial System	Repair System	Other Factors (.1946): Site Classification (.1948): PS Evaluated By: BM Others Present:
Available Space (.1945)	✓	✓	
System Type(s)	25% ₂	25% ₂	
Site LTAR	.3	.3	