

**SOIL/SITE EVALUATION
 for ON-SITE WASTEWATER SYSTEM**

Owner: Applicant:

Address: Date Evaluated: 2/21/13
 Proposed Facility: 3 2000 Design Flow (.1949): 36000

Property Size:

Location of Site: Property Recorded:
 Water Supply: Public Individual Well Spring Other
 Evaluation Method: Auger Boring Pit Cut
 Type of Wastewater: Sewage Industrial Process Mixed

P R O F I L E #	.1940 Landscape Position/ Slope %	Horizon Depth (In.)	SOIL MORPHOLOGY .1941		OTHER PROFILE FACTORS				Profile Class & LTAR
			.1941 Structure/ Texture	.1941 Consistence Mineralogy	.1942 Soil Wetness/ Color	.1943 Soil Depth (IN.)	.1956 Sapro Class	.1944 Restr Horiz	
1	LS 25	0-6"	G LS	VFD NS/HP					
		6-11"	C		10YR2/2e 18"				US
2		0-26	G LS	VFD NS/HP					
		26-31	SBK SCL	F2 SS/HP					
		31-36"	SBK SCL	F2 SS/SP	10YR2/2e 33"				P5 24
3		0-27	G LS	VFD NS/HP					
		27-36	SBK SCL	F2 SS/HP					
		36-42"	SBK SCL	F2 SS/SP	10YR2/2e 38"				P5 24

Description	Initial System	Repair System	Other Factors (.1946): Site Classification (.1948): P5 Evaluated By: [Signature] Others Present:
Available Space (.1945)			
System Type(s)	PUMP 25%		
Site LTAR	2	2	