

**SOIL/SITE EVALUATION**  
**for ON-SITE WASTEWATER SYSTEM**

Owner:                      Applicant:  
 Address:                      Date Evaluated: 3/20/13  
 Proposed Facility: 3 BRMS      Design Flow (.1949) 360 GPD  
 Location of Site:              Property Recorded:  
 Water Supply:               Public  Individual  Well  Spring  Other  
 Evaluation Method:  Auger Boring  Pit  Cut  
 Type of Wastewater:  Sewage  Industrial Process  Mixed

P R O F I L E #	.1940 Landscape Position/ Slope %	Horizon Depth (In.)	SOIL MORPHOLOGY		OTHER PROFILE FACTORS				Profile Class & LTAR
			.1941		.1942 Soil Wetness/ Color	.1943 Soil Depth (IN.)	.1956 Sapro Class	.1944 Restr Horiz	
			.1941 Structure/ Texture	.1941 Consistence Mineralogy					
1	LS 2.5	0-20	GS	VFR NS/NP					
		20-33	SBK SCL	FR SS/NP	10YR 7/2 @ 33"				P3 .45
			MAN @ 33" ROOT						
2		0-42	GS	VFR NS/NP					
		42-48	SBK SCL	FR SS/NP					P3 .45
3		0-23	GS	VFR NS/NP					
		23-40	SBK SCL	FR SS/NP	10YR 7/2 @ 34"				P3 .45

Description	Initial System <input checked="" type="checkbox"/>	Repair System <input checked="" type="checkbox"/>	Other Factors (.1946): Site Classification (.1948): P3 Evaluated By: [Signature] Others Present: -
Available Space (.1945)			
System Type(s)	2-3' x 2' x 2'		
Site LTAR	.45	.45	

1 x 200 @ 18" = REPAIR