Department of Environment, Health and Natural Resources
Division of Environmental Health
On-Site Wastewater Section

Sheet:
Property ID:
Lot #:
File #:
Code:

SOIL/SITE EVALUATION
for ON-SITE WASTEWATER SYSTEM

Owner: Applicant:
Address: Date Evaluated: 4/16
Proposed Facility: 4 bedroom Design Flow (.1949): 480 gpd Property Size:
Location of Site: Property Recorded:
Water Supply: ☒ Public ☐ Individual ☐ Well ☐ Spring ☐ Other
Evaluation Method: ☒ Auger Boring ☐ Pit ☐ Cut
Type of Wastewater: ☒ Sewage ☐ Industrial Process ☐ Mixed

PROFILE #	.1940 Landscape Position/ Slope %	Horizon Depth (In.)	SOIL MORPHOLOGY .1941		OTHER PROFILE FACTORS				Profile Class & LTAR
			.1941 Structure/ Texture	.1941 Consistence Mineralogy	.1942 Soil Wetness/ Color	.1943 Soil Depth (IN.)	.1956 Sapro Class	.1944 Restr Horiz	
1	LS 5-7	0-20	G S	VFR NS/NP					
		20-48	SBK SCL	FR SS/SP					PS .4
2		0-10	G S	VFR NS/NP					
		10-48	SBK SCL	FR SS/SP					PS .4

Description	Initial System	Repair System
Available Space (.1945)	✓	/
System Type(s)	PVMP 25'/ft	
Site LTAR	.4	.4

Other Factors (.1946): PS
Site Classification (.1948): PS
Evaluated By: OK
Others Present: —