

County of Harnett
Building Inspections Department
Planning Services

Certificate of Compliance: _____ Occupancy: x

Certificate issued pursuant to the requirements of North Carolina General Statute 153A-363 and Harnett County Zoning Ordinances. This certifies at the time of issuance, this structure was in compliance with the various ordinances of the County of Harnett and the North Carolina State Building Codes. For the following:

Use Classification: SFD

Permit Numbers

Name: Gregory Inc

Building: 13-50030971

Electrical: 13-50030971

Address: 2595 Kipling Road

Insulation: 13-50030971

Fuquay Varina NC 27526

Plumbing: 13-50030971

Mechanical: 13-50030971

MFG Home: //////////

Date: 10-08-2013

Building Official: BSutton

ADDRESS : 2595 KIPLING RD SUBDIV:
 CONTRACTOR : GREGORY INC PHONE : (919) 639-6101
 OWNER : GREGORY INC PHONE :
 PARCEL : 08-0652- - -0049- - -
 APPL NUMBER: 13-50030971 CP NEW RESIDENTIAL (SFD)
 DIRECTIONS : T/S: 04/03/2013 08:51 AM VBROWN ----
 2595 KIPLING ROAD. 401N, LEFT ON
 KIPLING RD, 2MI ON LEFT PAST HARDEE RD.
 T/S: 05/14/2013 08:07 AM VBROWN ----
 PREMIS NUMBER 61747731

STRUCTURE: 000 000 35X60 3BDR 2BDR DECK CRAWL

FLOOD ZONE : FLOOD ZONE X
 # BEDROOMS : 3.00 PROPOSED USE : SFD
 SEPTIC - EXISTING? : EXISTING WATER SUPPLY : EXISTING WELL

PERMIT: CPSF 00 CP * SFD

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
B101 01	5/07/13 5/07/13	BS DP	R*BLDG FOOTING / TEMP SVC POLE TIME: 17:00 VRU #: 002373496 T/S: 04/25/2013 01:31 PM VBROWN ---- T/S: 04/29/2013 09:22 AM VBROWN ---- T/S: 04/30/2013 03:45 PM VBROWN ---- T/S: May 07, 2013 08:44 AM BSUTTON ---- No footing dug. No one here working at 9 am. No call to cancel inspection. No inspection box to leave this ticket in. \$50 re fee T/S: May 07, 2013 08:44 AM BSUTTON ----
B101 02	5/14/13 5/14/13	BS AP	R*BLDG FOOTING / TEMP SVC POLE TIME: 17:00 VRU #: 002381333 T/S: 05/13/2013 08:37 AM VBROWN ---- T/S: May 14, 2013 01:55 PM BSUTTON ----
A814 01	5/20/13 5/22/13	TW AP	ADDRESS CONFIRMATION TIME: 17:00 VRU #: 002384121 2595 kipling rd fuquay varina 27526 ---- T/S: 05/22/2013 11:03 AM TWARD ----
B103 01	5/20/13 5/20/13	BS AP	R*BLDG FOUND & TEMP SVC POLE TIME: 17:00 VRU #: 002384113 T/S: 05/17/2013 10:02 AM VBROWN ---- T/S: May 20, 2013 12:08 PM BSUTTON ----
B105 01	5/28/13 5/28/13	KS AP	R*OPEN FLOOR TIME: 17:00 VRU #: 002387264 T/S: 05/24/2013 08:51 AM DJOHNSON ---- T/S: 05/28/2013 01:38 PM KSLATTUM ----
R425 01	6/26/13 6/26/13	BS AP	FOUR TRADE ROUGH IN TIME: 17:00 VRU #: 002402378 T/S: 06/25/2013 08:52 AM VBROWN ---- T/S: June 26, 2013 09:55 AM BSUTTON ----
I129 01	6/28/13 6/28/13	BS DA	R*INSULATION INSPECTION TIME: 17:00 VRU #: 002404804 T/S: 06/28/2013 11:38 AM VBROWN ---- T/S: June 28, 2013 11:53 AM BSUTTON ---- Wall insulation must be R-15 not R 13
I129 02	7/01/13 7/01/13	BS AP	R*INSULATION INSPECTION TIME: 17:00 VRU #: 002404903 T/S: July 01, 2013 08:54 AM BSUTTON ----
H824 01	9/13/13 9/13/13	JM AP	ENVR. OPERATIONS PERMIT TIME: 17:00 VRU #: 002439511 T/S: 09/13/2013 11:25 AM SSTEWARD ---- T/S: 09/13/2013 11:25 AM SSTEWARD ----
R429 01	10/04/13 10/04/13	DT DA	FOUR TRADE FINAL TIME: 17:00 VRU #: 002448744 T/S: 10/03/2013 11:07 AM VBROWN ---- T/S: 10/04/2013 03:48 PM DETAYLOR ----

ADDRESS : 2595 KIPLING RD
CONTRACTOR : GREGORY INC
OWNER : GREGORY INC
PARCEL : 08-0652- - -0049- - -
APPL NUMBER: 13-50030971 CP NEW RESIDENTIAL (SFD)

SUBDIV:
PHONE : (919) 639-6101
PHONE :

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
R429 02	10/07/13 10/07/13	BS DA	No energy efficiency certificate FOUR TRADE FINAL TIME: 17:00 VRU #: 002449593 T/S: October 07, 2013 10:10 AM BSUTTON
R429 03	10/08/13 <u>10.8.13</u>	TI <u>AOBS</u>	Energy certificate must be filled out by builder FOUR TRADE FINAL TIME: 17:00 VRU #: 002450146 T/S: 10/07/2013 02:09 PM DJOHNSON

COMMENTS AND NOTES

ADDRESS : 2595 KIPLING RD SUBDIV:
 CONTRACTOR : GREGORY INC PHONE : (919) 639-6101
 OWNER : GREGORY INC PHONE :
 PARCEL : 08-0652- - -0049- - -
 APPL NUMBER: 13-50030971 CP NEW RESIDENTIAL (SFD)
 DIRECTIONS : T/S: 04/03/2013 08:51 AM VBROWN ----
 2595 KIPLING ROAD. 401N, LEFT ON
 KIPLING RD, 2MI ON LEFT PAST HARDEE RD.
 T/S: 05/14/2013 08:07 AM VBROWN ----
 PREMIS NUMBER 61747731

STRUCTURE: 000 000 35X60 3BDR 2BDR DECK CRAWL

FLOOD ZONE : FLOOD ZONE X
 # BEDROOMS : 3.00 PROPOSED USE : SFD
 SEPTIC - EXISTING? : EXISTING WATER SUPPLY : EXISTING WELL

PERMIT: CPSF 00 CP * SFD

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
B101 01	5/07/13 5/07/13	BS DP	R*BLDG FOOTING / TEMP SVC POLE TIME: 17:00 VRU #: 002373496 T/S: 04/25/2013 01:31 PM VBROWN ---- T/S: 04/29/2013 09:22 AM VBROWN ---- T/S: 04/30/2013 03:45 PM VBROWN ---- T/S: May 07, 2013 08:44 AM BSUTTON ---- No footing dug. No one here working at 9 am. No call to cancel inspection. No inspection box to leave this ticket in. \$50 re fee T/S: May 07, 2013 08:44 AM BSUTTON ----
B101 02	5/14/13 5/14/13	BS AP	R*BLDG FOOTING / TEMP SVC POLE TIME: 17:00 VRU #: 002381333 T/S: 05/13/2013 08:37 AM VBROWN ---- T/S: May 14, 2013 01:55 PM BSUTTON ----
A814 01	5/20/13 5/22/13	TW AP	ADDRESS CONFIRMATION TIME: 17:00 VRU #: 002384121 2595 kipling rd fuquay varina 27526 ---- T/S: 05/22/2013 11:03 AM TWARD ----
B103 01	5/20/13 5/20/13	BS AP	R*BLDG FOUND & TEMP SVC POLE TIME: 17:00 VRU #: 002384113 T/S: 05/17/2013 10:02 AM VBROWN ---- T/S: May 20, 2013 12:08 PM BSUTTON ----
B105 01	5/28/13 <i>5-28</i>	TI <i>AP</i>	R*OPEN FLOOR TIME: 17:00 VRU #: 002387264 T/S: 05/24/2013 08:51 AM DJOHNSON ----

COMMENTS AND NOTES