

**SOIL/SITE EVALUATION
 for ON-SITE WASTEWATER SYSTEM**

Owner: Applicant:
 Address: Date Evaluated:
 Proposed Facility: **3 BORN** Design Flow (.1949): **360 gpd** Property Size:
 Location of Site: Property Recorded:
 Water Supply: Public Individual Well Spring Other
 Evaluation Method: Auger Boring Pit Cut
 Type of Wastewater: Sewage Industrial Process Mixed

P R O F I L E #	.1940 Landscape Position/ Slope %	Horizon Depth (In.)	SOIL MORPHOLOGY .1941		OTHER PROFILE FACTORS				Profile Class & LTAR
			.1941 Structure/ Texture	.1941 Consistence Mineralogy	.1942 Soil Wetness/ Color	.1943 Soil Depth (IN.)	.1956 Sapro Class	.1944 Restr Horiz	
		0-20	G S	VF L NS / NP					
		20-30	SBX C	FR S / P					PS .3
		30"	SBX C		10727/2030"				
		0-32	G S	VF L NS / NP					
		32-39	SBX CL	FR NS / NP					PS .5
		39"			10727/2039"				
		0-26	G S	VF L NS / NP					
		26-30	SBX CL	FR SS / SP					PS .4
		30	PA						
		0-35	G S	VF L NS / NP					
		35-42	G SL	VF L NS / NP					PS .2
			VF L NS / NP						
		0-36	G S	VF L NS / NP					
		36-40	G SL	VF L NS / NP					PS .8

Description	Initial System <input checked="" type="checkbox"/>	Repair System <input checked="" type="checkbox"/>	Other Factors (.1946):
Available Space (.1945)			Site Classification (.1948): PS
System Type(s)	25' x 60"	PUMP	Evaluated By: OS
Site LTAR	.5	.3	Others Present: -