Department of Environment, Health and Natural Resources
Division of Environmental Health
On-Site Wastewater Section

Sheet:
Property ID:
Lot #:
File #:
Code:

## SOIL/SITE EVALUATION
## for ON-SITE WASTEWATER SYSTEM

Owner: Applicant:
Address: Date Evaluated: 5/1/23
Proposed Facility: 3 BDRM Design Flow (.1949): 360 gpd Property Size:
Location of Site: Property Recorded:
Water Supply: ☒ Public ☐ Individual ☐ Well ☐ Spring ☐ Other
Evaluation Method: ☒ Auger Boring ☐ Pit ☐ Cut
Type of Wastewater: ☒ Sewage ☐ Industrial Process ☐ Mixed

| PROFILE # | .1940 Landscape Position/ Slope % | Horizon Depth (In.) | SOIL MORPHOLOGY .1941 | | OTHER PROFILE FACTORS | | | | Profile Class & LTAR |
|---|---|---|---|---|---|---|---|---|---|
| | | | .1941 Structure/ Texture | .1941 Consistence Mineralogy | .1942 Soil Wetness/ Color | .1943 Soil Depth (IN.) | .1956 Sapro Class | .1944 Restr Horiz | |
| 1 | LS 7-10 | 0-30" | G S | VFR NS/NP | | | | | |
| | | 30-40" | SBK SCL | FR SS/SP | | | | | PS .24 |
| | | | | | | | | | |
| 2 | | 0-39 | G S | VFR NS/NP | | | | | |
| | | 39-42 | G SL | VFR NS/NP | | | | | S .6 |
| | | | | | | | | | |
| 3 | | 0-36 | G S | VFR NS/NP | | | | | |
| | | 36-42 | SBK SCL | FR SS/NP | | | | | PS .8 |
| | | | | | | | | | |
| | | | | | | | | | |
| | | | | | | | | | |
| | | | | | | | | | |
| | | | | | | | | | |
| | | | | | | | | | |
| | | | | | | | | | |
| | | | | | | | | | |
| | | | | | | | | | |
| | | | | | | | | | |
| | | | | | | | | | |

| Description | Initial System | Repair System |
|---|---|---|
| Available Space (.1945) | ✓ | ✓ |
| System Type(s) | 25% | RED |
| Site LTAR | .5 | .4 |

Other Factors (.1946):
Site Classification (.1948): PS
Evaluated By: CT
Others Present: BM