

**SOIL/SITE EVALUATION  
 for ON-SITE WASTEWATER SYSTEM**

Owner:                      Applicant: *S. Powell*  
 Address:                      Date Evaluated: *5-23-13*  
 Proposed Facility: *SFD*                      Design Flow (.1949): *360*                      Property Size:  
 Location of Site:                      Property Recorded:  
 Water Supply:                       Public  Individual     Well                       Spring                       Other  
 Evaluation Method:  Auger Boring                       Pit                       Cut  
 Type of Wastewater:                       Sewage                       Industrial Process                       Mixed

P R O F I L E #	.1940 Landscape Position/ Slope %	Horizon Depth (In.)	SOIL MORPHOLOGY .1941		OTHER PROFILE FACTORS				Profile Class & LTAR
			.1941 Structure/ Texture	.1941 Consistence Mineralogy	.1942 Soil Wetness/ Color	.1943 Soil Depth (IN.)	.1956 Sapro Class	.1944 Restr Horiz	
1,2	L <sup>3</sup> / <sub>10</sub>	0-12	SL	CLAY SAND					
		12-46	SC-CLAY	FIN 1.5BK S.P.	42" 7.5g <sub>2</sub>				.3
3,4,5	L <sup>3</sup> / <sub>10</sub>	0-10	SL	CLAY SAND					
		10-42	SC-CLAY	FIN 1.5BK S.P.	36" 7.5g <sub>2</sub>				.3

Description	Initial System	Repair System	Other Factors (.1946): Site Classification (.1948): <i>75</i> Evaluated By: <i>2</i> Others Present:
Available Space (.1945)	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	
System Type(s)	<i>25"</i>	<i>25"</i>	
Site LTAR	<i>.3</i>	<i>.3</i>	