Department of Environment, Health and Natural Resources
Division of Environmental Health
On-Site Wastewater Section

Sheet:
Property ID:
Lot #:
File #:
Code:

SOIL/SITE EVALUATION
for ON-SITE WASTEWATER SYSTEM

Owner: Applicant: SAMER
Address: Date Evaluated:
Proposed Facility: SFM Design Flow (.1949): 360 Property Size:
Location of Site: Property Recorded:
Water Supply: ☑ Public ☐ Individual ☐ Well ☐ Spring ☐ Other
Evaluation Method: ☑ Auger Boring ☐ Pit ☐ Cut
Type of Wastewater: ☑ Sewage ☐ Industrial Process ☐ Mixed

PROFILE #	.1940 Landscape Position/ Slope %	Horizon Depth (In.)	SOIL MORPHOLOGY .1941		OTHER PROFILE FACTORS				Profile Class & LTAR
			.1941 Structure/ Texture	.1941 Consistence Mineralogy	.1942 Soil Wetness/ Color	.1943 Soil Depth (IN.)	.1956 Sapro Class	.1944 Restr Horiz	
1	L 4%	0-20	SL	FR GR NSNP					
		20-42	SC-clay	Fm/VFR SBK S.P.	34-38 7.5YR 7/1				.3
2,3,4	L-3%	0-30	SL	FR GR NSNP					
		30-48	SC-clay loam	Fm/FR SBK S.P.	44" 7.5YR 3/1				.55 7.4
5	L-4%	0-20	SL	FR GR NSNP					
		20-42	SC-clay loam	Fm/FR SBK S.P.	36-38 7.5YR 3/1				.3

Description	Initial System	Repair System
Available Space (.1945)	/	/
System Type(s)	25%	25%
Site LTAR	.3	.3

Other Factors (.1946):
Site Classification (.1948): PS
Evaluated By:
Others Present: