

**SOIL/SITE EVALUATION  
 for ON-SITE WASTEWATER SYSTEM**

Owner:                      Applicant: *Ralph Page - 1000 J. Cannon Avenue*  
 Address:                    Date Evaluated:  
 Proposed Facility: *SFD*                      Design Flow (.1949): *480*                      Property Size:  
 Location of Site:                      Property Recorded:  
 Water Supply:                       Public  Individual                       Well                       Spring                       Other  
 Evaluation Method:  Auger Boring                       Pit                       Cut  
 Type of Wastewater:                       Sewage                       Industrial Process                       Mixed

P R O F I L E #	.1940 Landscape Position/ Slope %	Horizon Depth (In.)	SOIL MORPHOLOGY .1941		OTHER PROFILE FACTORS				Profile Class & LTAR
			.1941 Structure/ Texture	.1941 Consistence Mineralogy	.1942 Soil Wetness/ Color	.1943 Soil Depth (IN.)	.1956 Sapro Class	.1944 Restr Horiz	
1,2,3	<i>L</i> 0-30	<i>SL</i>	<del><i>SL</i></del>	<i>LK GRASSY</i>					
	<i>30-48</i>	<i>SL</i>	<i>Grnd 30W</i>	<i>ln 150K S.P.</i>	<i>40" 2.5W 3.1</i>				<i>.4</i>
4,5	0-24	<i>SL</i>		<i>PK GRASSY</i>					
	<i>24-40</i>	<i>SL-CL</i>		<i>Grnd 30W</i>	<i>36-38 7.5W 3.1</i>				<i>.35</i>
6	0-30	<i>SL</i>		<i>PK GRASSY</i>					
	<i>30-48</i>	<i>SL-CL</i>		<i>Grnd 30W</i>	<i>42" 2.5W 3.1</i>				<i>.4</i>
7	0-24	<i>SL</i>		<i>PK GRASSY</i>					
	<i>24-40</i>	<i>SL-CL</i>		<i>Grnd 30W</i>	<i>38" 7.5W 3.1</i>				<i>.35</i>

Description	Initial System <input checked="" type="checkbox"/>	Repair System <input type="checkbox"/>	Other Factors (.1946): Site Classification (.1948): Evaluated By: <i>[Signature]</i> Others Present:
Available Space (.1945)	<i>2500</i>	<i>2500</i>	
System Type(s)	<i>2500</i>	<i>2500</i>	
Site LTAR	<i>.4</i>	<i>.4</i>	