HTE# <u>13-5-31671</u> Harnett County Department of Public Health 24396
A building permit cannot be issued with only an Improvement Permit
ISSUED TO: SAVAY HOMES LLC SUBDIVISION MAMIE BELL RIDEC LOT # G3A
NEW X REPAIR C EXPANSION C Site Improvements required prior to Construction Authorization Issuance:
Proposed Wastewater System Type: 25% REDUCTION
Projected Daily Flow: <u>480</u> GPD Number of bedrooms: <u>4</u> Number of Occupants: <u>8</u> max
Basement 🗆 Yes 🔀 No
Pump Required: 🗌 Yes 🔲 No 🔪 May be required based on final location and elevations of facilities
Type of Water Supply: Community Rublic Well Distance from well <u>100</u> feet Permit valid for: Five years Permit conditions: No expiration
Jeff 10
Authorized State Agent::
The issuance of this permit by the Health Department in no way guarantees the issuance of other permits. The permit holder is responsible for checking with appropriate governing bodies in meeting
their requirements. This site is subject to revocation if the site plan, plat, or the intended use changes. The Improvement Permit shall not be affected by a change in ownership of the site. This permit is subject to compliance with the provisions of the Laws and Rules for Sewage Treatment and Disposal and to conditions of this permit.
Construction Authorization
(Required for Building Permit)
The construction and installation requirements of Rules .1950, .1952, .1954, .1955, .1956, .1957, .1958. and .1959 are incorporated by references into this permit and shall be met. Systems shall be installed in accordance with the attached system layout.
ISSUED TO: SAN JY HOME'S LLC PROPERTY LOCATION: OLD 421
Facility Type: SED (58×45) SUBDIVISION MANIE BELL RIOGE LOT # 63A
Basement? 🗆 Yes 🛛 🔀 No 🛛 Basement Fixtures? 🔲 Yes 🖂 No
Type of Wastewater System** <u>25% REDUCTION (Initial)</u> Wastewater Flow: <u>480</u> GPD
(See note below, if applicable) Pume To 25% REDUCTIVA (Repair)
Installation Requirements/Conditions
Septic Tank Size 1000 gallonsExact length of each trench 12000 feetTrench Spacing: 9 Feet on CenterPump Tank Size 10000 gallonsTrenches shall be installed on contour at aSoil Cover: 12 inches
Pump Tank Size <u>LOOO</u> gallons Trenches shall be installed on contour at a Soil Cover: <u>12</u> inches (1F NEEDED) Maximum Trench Depth of: <u>24</u> inches (Maximum soil cover shall not exceed
(Trench bottoms shall be level to $+/-1/4$ " 36" above the trench bottom)
in all directions)
Pump Requirements:ft. TDH vs GPM inches below pipe
Conditions: IF PUMP 15 NEEDED SWITCH WITIAZ & REPAIR Aggregate Depth: inches above pipe inches total
**If applicable: I understand the system type specified is different from the type specified on the application. I accept the specifications of this permit.
Owner/Level Reconceptation Signatures
Owner/Legal Representative Signature: Date: Date: Date: Date: Date: Date:
of the site. This Construction Authorization is subject to compliance with the provisions of the Laws and Rules for Sewage Treatment and Disposal and to the conditions of this permit.
Authorized State Arent:
Authorized State Agent: Date: 8 13 3 Construction Authorization Expiration Date: 9 13 18



