

HTE# 13-5-31613
13-5-31684

Harnett County Department of Public Health

Improvement Permit

27542

A building permit cannot be issued with only an Improvement Permit

PROPERTY LOCATION: HOLLY SPRINGS GARDEN RD

ISSUED TO: SAMMY McNEILL SUBDIVISION _____ LOT # _____

NEW REPAIR EXPANSION Site Improvements required prior to Construction Authorization Issuance: _____
Type of Structure: SFD(65x75) STORAGE W/ LIVING AREA

Proposed Wastewater System Type: 25% REDUCTION

Projected Daily Flow: 480 GPD

Number of bedrooms: 4 Number of Occupants: 8 max

Basement Yes No

Pump Required: Yes No May be required based on final location and elevations of facilities

Type of Water Supply: Community Public Well Distance from well 100 feet

Permit valid for: Five years
 No expiration

Permit conditions: _____

Authorized State Agent: [Signature] Date: 8/5/13 SEE ATTACHED SITE SKETCH

The issuance of this permit by the Health Department in no way guarantees the issuance of other permits. The permit holder is responsible for checking with appropriate governing bodies in meeting their requirements. This site is subject to revocation if the site plan, plat, or the intended use changes. The Improvement Permit shall not be affected by a change in ownership of the site. This permit is subject to compliance with the provisions of the Laws and Rules for Sewage Treatment and Disposal and to conditions of this permit.

Construction Authorization

(Required for Building Permit)

The construction and installation requirements of Rules .1950, .1952, .1954, .1955, .1956, .1957, .1958, and .1959 are incorporated by references into this permit and shall be met. Systems shall be installed in accordance with the attached system layout.

ISSUED TO: SAMMY McNEILL PROPERTY LOCATION: HOLLY SPRINGS CRT RD

SUBDIVISION _____ LOT # _____

Facility Type: SFD + STORAGE W/ LIVING AREA New Expansion Repair

Basement? Yes No Basement Fixtures? Yes No

Type of Wastewater System** 25% REDUCTION SYSTEM (Initial) Wastewater Flow: 480 GPD

(See note below, if applicable) PUMP TO 25% REDUCTION (Repair)

Installation Requirements/Conditions

Septic Tank Size 1000 gallons

Pump Tank Size 1000 gallons

(IF NEEDED)

Number of trenches 1

Exact length of each trench 350 feet

Trenches shall be installed on contour at a

Maximum Trench Depth of: 18 inches

(Trench bottoms shall be level to +/-1/4"

in all directions)

Trench Spacing: 9 Feet on Center

Soil Cover: 6 inches

(Maximum soil cover shall not exceed

36" above the trench bottom)

Pump Requirements: _____ ft. TDH vs. _____ GPM _____ inches below pipe

Aggregate Depth: _____ inches above pipe

Conditions: SEE CONDITIONS ON SITE SKETCH _____ inches total

WATER LINES (INCLUDING IRRIGATION) MUST BE 10FT. FROM ANY PART OF SEPTIC SYSTEM OR REPAIR AREA.

NO UTILITIES ALLOWED IN INITIAL OR REPAIR DRAIN FIELD AREA.

**If applicable: I understand the system type specified is different from the type specified on the application. I accept the specifications of this permit.

Owner/Legal Representative Signatures: _____ Date: _____

This Construction Authorization is subject to revocation if the site plan, plat, or the intended use changes. The Construction Authorization shall not be transferred when there is a change in ownership of the site. This

Construction Authorization is subject to compliance with the provisions of the Laws and Rules for Sewage Treatment and Disposal and to the conditions of this permit.

SEE ATTACHED SITE SKETCH

Authorized State Agent: [Signature] Date: 8/5/13

Construction Authorization Expiration Date: 7/5/14


HTE# 13-5-31683
13-5-31684

Permit # 27542

Harnett County Department of Public Health Site Sketch

ISSUED TO: Sammy McNEILL PROPERTY LOCATOR: HOLLY SPRINGS CH. R.
SUBDIVISION _____ LOT # _____

Authorized State Agent: ~~_____~~ RENS (OLIVER TORRES) Date: 8/5/13



* RUN PLUMBING FROM BOTH STRUCTURES INTO ONE TANK.

* IF PUMP IS NEEDED BASED ON FINAL STRUCTURE ELEVATIONS THEN TANKS MAY BE MOVED. CALL HCHO TO VERIFY.