

**SOIL/SITE EVALUATION
 for ON-SITE WASTEWATER SYSTEM**

Owner: Applicant:
 Address: Date Evaluated:
 Proposed Facility: 3000m Design Flow (.1949): 360 gpd Property Size:
 Location of Site: Property Recorded:
 Water Supply: Public Individual Well Spring Other
 Evaluation Method: Auger Boring Pit Cut
 Type of Wastewater: Sewage Industrial Process Mixed

P R O F I L E #	.1940 Landscape Position/ Slope %	Horizon Depth (In.)	SOIL MORPHOLOGY .1941		OTHER PROFILE FACTORS				Profile Class & LTAR
			.1941 Structure/ Texture	.1941 Consistence Mineralogy	.1942 Soil Wetness/ Color	.1943 Soil Depth (IN.)	.1956 Sapro Class	.1944 Restr Horiz	
1	<u>LS 7-10</u>	<u>0-24</u>	<u>G S</u>	<u>VF2 NS/MP</u>					
		<u>24-2</u>	<u>G SL</u>	<u>VF2 NS/MP</u>					
		<u>2-11</u>	<u>SBC SL</u>	<u>FR SS/SP</u>					<u>PS .5</u>
2		<u>0-28</u>	<u>G S</u>	<u>VF2 NS/MP</u>					
		<u>28-36</u>	<u>SBC SL</u>	<u>FR NS/MP</u>					<u>PS .55</u>
3		<u>0-18</u>	<u>G S</u>	<u>VF2 NS/MP</u>					
		<u>18-33</u>	<u>G SL</u>	<u>VF2 NS/MP</u>					
		<u>32</u>	<u>SBC SL</u>	<u>FR SS/SP</u>					<u>PS .5</u>

Description	Initial System	Repair System	Other Factors (.1946): Site Classification (.1948): <u>PS</u> Evaluated By: <u>OT</u> Others Present: <u>-</u>
Available Space (.1945)	<u>✓</u>	<u>✓</u>	
System Type(s)	<u>PUMP</u>	<u>25%</u>	
Site LTAR	<u>.5</u>	<u>.5</u>	

1x180' e 18"