

**SOIL/SITE EVALUATION
 for ON-SITE WASTEWATER SYSTEM**

Owner: Applicant: BARC
 Address: Date Evaluated:
 Proposed Facility: SFD Design Flow (.1949): 300 Property Size:
 Location of Site: Property Recorded:
 Water Supply: Public Individual Well Spring Other
 Evaluation Method: Auger Boring Pit Cut
 Type of Wastewater: Sewage Industrial Process Mixed

P R O F I L E #	.1940 Landscape Position/ Slope %	Horizon Depth (In.)	SOIL MORPHOLOGY .1941		OTHER PROFILE FACTORS				Profile Class & LTAR
			.1941 Structure/ Texture	.1941 Consistence Mineralogy	.1942 Soil Wetness/ Color	.1943 Soil Depth (IN.)	.1956 Sapro Class	.1944 Restr Horiz	
1	L 45	0-24	SL WITH gravel in Gr 25 NP						
		24-48	SCL	fm 1 st 25 S.P.	42	25 31			.45
2	L 45	0-20	SL - gravel in Gr 23 NP						
		20-28	SCL	fm 1 st 25 S.P.	40	25 31			.4
3	L 5	0-18	SL Gravel in Gr 23 NP						
		18-42	SCL	fm 1 st 25 S.P.	38	25 31			.4
4	L 5	0-14	SL	fm Gr 23 NP					
		14-40	SCL - clay	fm 1 st 25 S.P.	36	38 31			.35
5	L 5	0-14	SL	fm Gr 23 NP					
		14-40	SCL - clay	fm 1 st 25 S.P.	36	25 31			.35

Description	Initial System	Repair System	Other Factors (.1946): Site Classification (.1948): Evaluated By: <u>[Signature]</u> Others Present:
Available Space (.1945)			
System Type(s)	<u>200</u>	<u>750</u>	
Site LTAR	<u>.01</u>	<u>.4-35</u>	