

**SOIL/SITE EVALUATION
 for ON-SITE WASTEWATER SYSTEM**

Owner: Applicant:
 Address: Date Evaluated: 9/3/13
 Proposed Facility: 4322M Design Flow (.1949): 480 gpd Property Size:
 Location of Site: Property Recorded:
 Water Supply: Public Individual Well Spring Other
 Evaluation Method: Auger Boring Pit Cut
 Type of Wastewater: Sewage Industrial Process Mixed

P R O F I L E #	.1940 Landscape Position/ Slope %	Horizon Depth (In.)	SOIL MORPHOLOGY .1941		OTHER PROFILE FACTORS				Profile Class & LTAR
			.1941 Structure/ Texture	.1941 Consistence Mineralogy	.1942 Soil Wetness/ Color	.1943 Soil Depth (IN.)	.1956 Sapro Class	.1944 Restr Horiz	
1	LS 2-5%	0-24	G S	VFI NS/VP					
		24-48	G SL	VFI NS/VP					S-5
2		0-24	G S	VFI NS/VP					
		24-48	G SL	VFI NS/VP					S-5
3		0-18	G S	VFI NS/VP					
		18-36	SBK SC	FI NS/VP					PS .45


Description	Initial System	Repair System	Other Factors (.1946): Site Classification (.1948): PS Evaluated By: [Signature] Others Present: [Signature]
Available Space (.1945)	✓	✓	
System Type(s)	2.5" (R) 6"		
Site LTAR	.5	.45	

3x75'

MAP NO. 2013-263

MAP REFERENCE: MAP NO. 2013-263

MINIMUM BUILDING SET BACKS
FRONT YARD — 25'
REAR YARD — 25'
SIDE YARD — 10'
CORNER LOT SIDE YARD — 20'
MAXIMUM HEIGHT — 35'



"OMAHA DRIVE" 50' R/W



SITE PLAN APPROVAL SFD
DISTRICT RA 20R USE SFD
#BEDROOMS 4
8-21-13 V.C. Davis
Zoning Administrator

SURVEY FOR
PROPOSED PLOT PLAN - LOT - 213
TINGEN POINTE S/D, PHASE - 4

BENNETT SURVEYS
1842 CLARK RD., LILLINGTON, N.C. 27546
(919) 895-5252

TOWNSHIP	BARBECUE	COUNTY	HARNETT	25' 0 50'	SURVEYED BY:	FIELD BOOK
STATE:	NORTH CAROLINA	DATE:	AUGUST 20, 2013	SCALE: 1" = 50'	DRAWN BY: RVB	DRAWING NO.
ZONE	RA-20R	WATERSHED DISTRICT:	TAX PARCEL ID#	CHECKED & CLOSURE BY:		13306