Department of Environment, Health and Natural Resources
Division of Environmental Health
On-Site Wastewater Section

Sheet:
Property ID:
Lot #:
File #:
Code:

SOIL/SITE EVALUATION
for ON-SITE WASTEWATER SYSTEM

Owner: Applicant: Sec 2
Address: Date Evaluated: 5-6-13
Proposed Facility: SFD Design Flow (.1949): 360 Property Size:
Location of Site: Property Recorded:
Water Supply: ☑ Public ☐ Individual ☐ Well ☐ Spring ☐ Other
Evaluation Method: ☐ Auger Boring ☐ Pit ☐ Cut
Type of Wastewater: ☐ Sewage ☐ Industrial Process ☐ Mixed

PROFILE #	.1940 Landscape Position/ Slope %	Horizon Depth (In.)	SOIL MORPHOLOGY .1941		OTHER PROFILE FACTORS				Profile Class & LTAR
			.1941 Structure/ Texture	.1941 Consistence Mineralogy	.1942 Soil Wetness/ Color	.1943 Soil Depth (IN.)	.1956 Sapro Class	.1944 Restr Horiz	
1	L-3%	0-24	SL	FR GR NSNP					
		24-42	SCL	FR/VFR SBK S.P.	38-40" 7.5YR 3.1				.4
2	L 2%	0-22	SL	FR GR NSNP					
		22-40	SCL	FR/VFR SBK S.P.	34-36" 7.5YR 3.1				.35
3	L	0-24	SL	FR GR NSNP					
		24-42	SCL	FR/VFR SBK S.P.	32-34 7.5YR 3.1				.35
4	L	0-20	SL	FR GR NSNP					
		20-40	SCL	FR/VFR SBK S.P.	34-36 7.5YR 3.1				.4

Description	Initial System	Repair System
Available Space (.1945)	✓	✓
System Type(s)	2 SFD	2 SFD
Site LTAR	.4	.35

Other Factors (.1946):
Site Classification (.1948): PS
Evaluated By:
Others Present: