

**SOIL/SITE EVALUATION  
 for ON-SITE WASTEWATER SYSTEM**

Owner:                      Applicant:  
 Address:                      Date Evaluated:  
 Proposed Facility: 4 BDRMS                      Design Flow (.1949): 480 gpd                      Property Size:  
 Location of Site:                      Property Recorded:  
 Water Supply:                       Public  Individual  Well  Spring  Other  
 Evaluation Method:  Auger Boring  Pit  Cut  
 Type of Wastewater:  Sewage  Industrial Process  Mixed

P R O F I L E #	.1940 Landscape Position/ Slope %	Horizon Depth (In.)	SOIL MORPHOLOGY .1941		OTHER PROFILE FACTORS				Profile Class & LTAR
			.1941 Structure/ Texture	.1941 Consistence Mineralogy	.1942 Soil Wetness/ Color	.1943 Soil Depth (IN.)	.1956 Sapro Class	.1944 Restr Horiz	
1	<u>LS 5-7</u>	<u>0-39</u>	<u>GS</u>	<u>VFZ NS/NP</u>					<u>S .8</u>
		<u>39</u>	<u>1R</u>						
2		<u>0-38</u>	<u>GS</u>	<u>VFZ NS/NP</u>					
		<u>38.42</u>	<u>S3X SCL</u>	<u>FL SS/NP</u>					<u>P3 .45</u>
		<u>0-38</u>	<u>GS</u>	<u>VFZ NS/NP</u>					
		<u>38</u>	<u>S3X SCL</u>	<u>FL SS/SP</u>					<u>P3.4</u>

Description	Initial System	Repair System	Other Factors (.1946): Site Classification (.1948): <u>P3</u> Evaluated By: <u>OR</u> Others Present: <u>-</u>
Available Space (.1945)	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	
System Type(s)	<u>2.5"/6 (2.5)</u>		
Site LTAR	<u>.4</u>	<u>.4</u>	