Department of Environment, Health and Natural Resources
Division of Environmental Health
On-Site Wastewater Section

Sheet:
Property ID:
Lot #:
File #:
Code:

SOIL/SITE EVALUATION
for ON-SITE WASTEWATER SYSTEM

Owner: Applicant: Wells
Address: Date Evaluated:
Proposed Facility: SFD+GAR Design Flow (.1949): 360 Property Size:
Location of Site: Fieldsa Property Recorded:
Water Supply: ☑ Public ☐ Individual ☐ Well ☐ Spring ☐ Other
Evaluation Method: ☐ ~~Auger Boring~~ ☐ Pit ☐ Cut
Type of Wastewater: ☑ Sewage ☐ Industrial Process ☐ Mixed

PROFILE #	.1940 Landscape Position/ Slope %	Horizon Depth (In.)	SOIL MORPHOLOGY .1941		OTHER PROFILE FACTORS				Profile Class & LTAR
			.1941 Structure/ Texture	.1941 Consistence Mineralogy	.1942 Soil Wetness/ Color	.1943 Soil Depth (IN.)	.1956 Sapro Class	.1944 Restr Horiz	
1,2	L 3%	0-10	SL	[illegible]					
		10-42	SC clay	Fr [illegible]	36-38 10R 3/1				
3	L 5%	0-8	SL	[illegible]					
		8-42	SC clay	Fr [illegible]	36 10R 3/1				
4	L 4%	0-12	SL	[illegible]					
		12-42	SC clay	Fr [illegible]	34-36 10R 3/1				

Description	Initial System	Repair System
Available Space (.1945)		
System Type(s)	LPS	LPS
Site LTAR	.3	.3

Other Factors (.1946):
Site Classification (.1948):
Evaluated By:
Others Present: