

**SOIL/SITE EVALUATION  
 for ON-SITE WASTEWATER SYSTEM**

Owner:                      Applicant:  
 Address:                      Date Evaluated:  
 Proposed Facility: 48 E 900m      Design Flow (.1949): 480 gpd      Property Size:  
 Location of Site:              Property Recorded:  
 Water Supply:               Public  Individual  Well       Spring       Other  
 Evaluation Method:  Auger Boring       Pit       Cut  
 Type of Wastewater:       Sewage       Industrial Process       Mixed

P R O F I L E #	.1940 Landscape Position/ Slope %	Horizon Depth (In.)	SOIL MORPHOLOGY .1941		OTHER PROFILE FACTORS				Profile Class & LTAR
			.1941 Structure/ Texture	.1941 Consistence Mineralogy	.1942 Soil Wetness/ Color	.1943 Soil Depth (IN.)	.1956 Sapro Class	.1944 Restr Horiz	
1	LS 2-5	0-12	G SL	VFA N3/4					
		12-34	SBK SLL	FR S/S	10127/2 @ 30"				PS .4
2		0-29	G LS	VFA N3/4					
		29-48	SBK SLL	FR S/S					PS .45
3		0-10"	SBK C	FR S/P	10127/2 @ 5"				US
		12"	pm						
4		0-28	G SL	VFA N5/6					PS .4
		28-38	SBK SLL	FR S/S					
5		0-12	G SL						
		12-30"	SBK SLL		10127/2 @ 28"				PS .4

Description	Initial System	Repair System	Other Factors (.1946): Site Classification (.1948): PS Evaluated By: OT Others Present: -
Available Space (.1945)	✓	✓	
System Type(s)	0 VMP	25% 26	
Site LTAR	24	14	

3-28 @ 17"  
4-75 @ 18"