Department of Environment, Health and Natural Resources
Division of Environmental Health
On-Site Wastewater Section

Sheet:
Property ID:
Lot #:
File #:
Code:

SOIL/SITE EVALUATION
for ON-SITE WASTEWATER SYSTEM

Owner: Applicant:
Address: Date Evaluated:
Proposed Facility: SFDOM Design Flow (.1949): 360gpd Property Size:
Location of Site: Property Recorded:
Water Supply: ☒ Public ☐ Individual ☐ Well ☐ Spring ☐ Other
Evaluation Method: ☒ Auger Boring ☐ Pit ☐ Cut
Type of Wastewater: ☐ Sewage ☐ Industrial Process ☐ Mixed

PROFILE #	.1940 Landscape Position/ Slope %	Horizon Depth (In.)	SOIL MORPHOLOGY .1941		OTHER PROFILE FACTORS				Profile Class & LTAR
			.1941 Structure/ Texture	.1941 Consistence Mineralogy	.1942 Soil Wetness/ Color	.1943 Soil Depth (IN.)	.1956 Sapro Class	.1944 Restr Horiz	
1	LS 2-5	0-12	G SL	VFR NS/NP					
		12-48	SBK SCL	FR SS/NP					PS .5
2		0-10	G SL	VFR NS/NP					
		10-48	SBK SCL	FR SS/NP					PS .5

Description	Initial System	Repair System
Available Space (.1945)	✓	✓
System Type(s)	0.5%	RED
Site LTAR	.5	.5

Other Factors (.1946):
Site Classification (.1948): PS
Evaluated By: OT
Others Present: —