

**SOIL/SITE EVALUATION
 for ON-SITE WASTEWATER SYSTEM**

Owner: Applicant: *[Signature]*
 Address: Date Evaluated:
 Proposed Facility: *3FD* Design Flow (.1949): *360* Property Size:
 Location of Site: Property Recorded:
 Water Supply: Public Individual Well Spring Other
 Evaluation Method: Auger Boring Pit Cut
 Type of Wastewater: Sewage Industrial Process Mixed

P R O F I L E #	.1940 Landscape Position/ Slope %	Horizon Depth (In.)	SOIL MORPHOLOGY .1941		OTHER PROFILE FACTORS				Profile Class & LTAR
			.1941 Structure/ Texture	.1941 Consistence Mineralogy	.1942 Soil Wetness/ Color	.1943 Soil Depth (IN.)	.1956 Sapro Class	.1944 Restr Horiz	
1.	L-122	0-8	SL-Low	SSS? SLCL MSH P					
		8-36	SEC-very	fm 188L S.P	30-71 ² 3-1				.3
2,3,4	L-128	0-4	LOW	fm 60 MSH P					
		4-24	SEC-very	fm 188L S.P	12-18 ⁵ 3-1				.2
5	L-24	0-10	SL	fm 60 MSH P					
		10-36	SEC-very	fm 188L S.P	30-72 ^{west} 3-1				.3
6,7	L-2	0-8	SL-Low	fm 60 MSH P					
		8-36	SL-Low	fm 188L S.P	24-26-28 ^{SL} 3-1				.3
8-10	L-27	0-8	SL	fm 60 MSH P					
		8-36	SEC-very	fm 188L S.P	30-32 ³⁻¹ 3-1				.3
9	L-2	6-4	S1-Low	fm 60 MSH P					
		4-24	SEC-very	fm 188L S.P	12 ⁷⁻¹				/

Description	Initial System	Repair System	Other Factors (.1946): Site Classification (.1948): Evaluated By: <i>[Signature]</i> Others Present: <i>[Signature]</i> + OT (8-9-10)
Available Space (.1945)	/	/	
System Type(s)	75 ²	75 ⁴	
Site LTAR	.3	.3-.25	