Harnett County Department of Public Health

HTE# 14-5-33073

27914

Im	prov	ement	Permit

A	building	permit	cannot	be	issued	with	only	an	Improvement	Permit	
---	----------	--------	--------	----	--------	------	------	----	-------------	--------	--

PROPERT	TY LOCATION: TILDEN HOWINGSON D2
ISSUED TO: DAYNY FLOWES LLC SUBDIVI	SION MAMIE BELL RIDCE LOT #90
NEW REPAIR REPAIR EXPANSION D	Site Improvements required prior to Construction Authorization Issuance:
Type of Structure: SED 151×50	
Proposed Wastewater System Type: 25% REDUCTION SYSTEM	
Projected Daily Flow: GPD	`
Number of bedrooms: Number of Occupants: max	
Number of bedrooms: Number of Occupants: max Basement □Yes No	
Pump Required: I Yes No I May be required based on final location an Type of Water Supply: Community Yellic Well Distance from w	d elevations of facilities
Type of Water Supply: 🗆 Community 🔀 Public 🗆 Well Distance from w	nd elevations of facilities vell <u>LOO</u> feet Permit valid for: Five years No expiration
Permit conditions:	
1 Ast 11	
Authorized State Agent.	

Construction Authorization

(Required for Building Permit)

The construction and installation requirements of Rules .1950, .1952, .1954, .1955, .1956, .1957, .1958. and .1959 are incorporated by references into this permit and shall be met. Systems shall be installed in accordance with the attached system layout.

ISSUED TO: SAVRY HOMES LLC PROPERTY LOCATION: TILDEN HOWINGTON DR	
SUBDIVISION MAMIE BELL BOGE LOT # 90 Facility Type: SFD (51×50) New I Expansion I Repair Basement? Yes No Basement Fixtures? Yes No Type of Wastewater System** 25% Reduction System (Initial) Wastewater Flow: 480 GF	5
Facility Type: <u>SFO(STX SO)</u> New Expansion Repair	
Basement? 🗆 Yes 🙈 No Basement Fixtures? 🗆 Yes 🔀 No	
Type of Wastewater System** _ 25% REDUCTION SYSTEM (Initial) Wastewater Flow: 480 GF	טי
	-
(see note below, 11 applicable []) 25% REDUCTION (Repair)	
Installation Requirements/Conditions Number of trenches 5	
Septic Tank Size 1000 gallons Exact length of each trench <u>50</u> feet Trench Spacing: <u>9</u> Feet on Center	
Pump Tank Size gallons Trenches shall be installed on contour at a Soil Cover: inches	
Maximum Trench Depth of: 18 inches (Maximum soil cover shall not exceed	
(Trench bottoms shall be level to $+/-1/4$ " 36" above the trench bottom)	
in all directions)	
Pump Requirements:ft. TDH vs GPMinches below	nine
Aggregate Depth: inches above	
Conditions: incles above	

WATER LINES (INCLUDING IRRIGATION) MUST BE 10FT. FROM ANY PART OF SEPTIC SYSTEM OR REPAIR AREA. NO UTILITIES ALLOWED IN INITIAL OR REPAIR DRAIN FIELD AREA.

**If applicable: I understand the system type specified is different from the type specified on the application. I accept the specifications of this permit.

Owner/Legal Representative Signature: Date:					
This Construction Authorization is subject to revocation if the site plan, plat, or the intended use changes. The Construction Authorization shall not be transferred when there is a change in ownership of the site. This					
Construction Authorization is subject to compliance with the provisions of the Laws and Rules for Sewage Treatment and Disposal and to the conditions of this permit.					
Authorized State Agent: Date:					

