

COUNTY OF HARNETT
Building Inspections Department
Planning Services

Certificate of Compliance: _____ **Occupancy:** ✓

Certificate issued pursuant to the requirements of North Carolina General Statute 153A-363 and Harnett County Zoning Ordinances. This certifies at the time of issuance, this structure was in compliance with the various ordinances of the County of Harnett and the North Carolina State Building Codes. For the following:

Use Classification: Residential

Name: Robert Crabtree

Address: 29 Tucson Ct.

Date: 11-5-14

Building Official: Ken Slatt

Permit Numbers

Building: _____

Electrical: _____

Insulation: _____

Plumbing: _____

Mechanical: _____

MFG Home: _____

14-0033306

ADDRESS : ~~29 TUCSON CT~~ SUBDIV: E J SMITH FARM
 CONTRACTOR : ROBERT CRABTREE BUILDERS INC PHONE : (919) 552-5897
 OWNER : ANDERSON ENTERPRISES INC PHONE : (919) 552-3383
 PARCEL : 08-0653- - -0105- -63-
 APPL NUMBER: 14-50033306 CP NEW RESIDENTIAL (SFD)
 DIRECTIONS : T/S: 04/07/2014 12:19 PM VBROWN ----
 29 TUCSON COURT FUQ VAR, VICTORIA HILLS
 II #215
 T/S: 06/30/2014 10:57 AM VBROWN ----
 premis number 8792244

STRUCTURE: 000 000 40X56 3BDR 2BATH SFD
 FLOOD ZONE : FLOOD ZONE X
 # BEDROOMS : 3.00 PROPOSED USE : SFD
 SEPTIC - EXISTING? : NEW TANK WATER SUPPLY : COUNTY

PERMIT: CPSF 00 CP * SFD

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
B101 01	6/26/14	BS	R*BLDG FOOTING / TEMP SVC POLE VRU #: 002547230
	6/26/14	AP	T/S: June 26, 2014 10:50 AM BSUTTON -----
E207 01	7/08/14	DT	R*ELEC TEMP SERVICE POLE TIME: 17:00 VRU #: 002551521
	7/08/14	AP	T/S: 07/07/2014 11:44 AM LSEGARS ----- T/S: 07/08/2014 10:20 AM DETAYLOR -----
A814 01	7/21/14	TW	ADDRESS CONFIRMATION TIME: 17:00 VRU #: 002556744
	7/18/14	AP	T/S: 07/18/2014 12:45 PM DJOHNSON ----- 29 Tucson Ct fuquay varina 27526 -- note: home faces tucson ct (not Mooney Dr) T/S: 07/18/2014 05:04 PM TWARD -----
B103 01	7/21/14	DT	R*BLDG FOUND & TEMP SVC POLE TIME: 17:00 VRU #: 002556736
	7/22/14	AP	T/S: 07/18/2014 12:45 PM DJOHNSON ----- T/S: 07/22/2014 09:59 AM DETAYLOR -----
B105 01	7/28/14	DT	R*OPEN FLOOR TIME: 17:00 VRU #: 002559458
	7/28/14	AP	T/S: 07/28/2014 02:12 PM DETAYLOR -----
R425 01	8/08/14	DT	FOUR TRADE ROUGH IN VRU #: 002564789
	8/08/14	AP	T/S: 08/08/2014 01:06 PM DETAYLOR -----
I129 01	8/12/14	KS	R*INSULATION INSPECTION VRU #: 002565844
	8/12/14	AP	T/S: 08/12/2014 04:03 PM KSLATTUM -----
H824 01	9/16/14	JM	ENVIR. OPERATIONS PERMIT TIME: 17:00 VRU #: 002579795
	9/16/14	AP	T/S: 09/17/2014 12:40 PM SSTEWARD ----- T/S: 09/17/2014 12:40 PM SSTEWARD -----
E209 01	10/03/14	MR	R*ELEC TEMP POWER CERT TIME: 17:00 VRU #: 002585214
	10/03/14	AP	T/S: 10/02/2014 01:21 PM LSEGARS ----- T/S: 10/03/2014 01:31 PM MREARIC -----
R429 01	10/29/14	KS	FOUR TRADE FINAL TIME: 17:00 VRU #: 002593374
	10/29/14	DA	T/S: 10/29/2014 10:57 AM KSLATTUM ----- 1. Need energy certificate. 2. Need fall protection devices on windows. 3. Need to close guard rail at top fo stairs or install ballisters no greater than 4 inches apart.
R429 02	11/05/14	TI	FOUR TRADE FINAL TIME: 17:00 VRU #: 002595734
	11/5-14	AP	T/S: 11/04/2014 01:11 PM LSEGARS -----

COMMENTS AND NOTES