

**COUNTY OF HARNETT**  
**Building Inspections Department**  
**Planning Services**

**Certificate of Compliance:** \_\_\_\_\_ **Occupancy:**

Certificate issued pursuant to the requirements of North Carolina General Statute 153A-363 and Harnett County Zoning Ordinances. This certifies at the time of issuance, this structure was in compliance with the various ordinances of the County of Harnett and the North Carolina State Building Codes. For the following:

Use Classification: Residential

Name: Robert Walter

Address: 189 Blairwood

Date: 11-5-14

Building Official: [Signature]

**Permit Numbers**  
Building: \_\_\_\_\_  
Electrical: \_\_\_\_\_  
Insulation: \_\_\_\_\_  
Plumbing: \_\_\_\_\_  
Mechanical: \_\_\_\_\_  
MFG Home: \_\_\_\_\_

14-50032306

ADDRESS : ~~189 BLAIRWOOD DR~~ SUBDIV: E J SMITH FARM  
CONTRACTOR : ROBERT CRABTREE BUILDERS INC PHONE : (919) 552-5897  
OWNER : ANDERSON ENTERPRISES INC PHONE : (919) 552-3383  
PARCEL : 08-0653- - -0105- -69-  
APPL NUMBER: 14-50033308 CP NEW RESIDENTIAL (SFD)  
DIRECTIONS : 189 BLAIRWOOD DR FUQ VAR, VICTORIA HILL  
II #222  
T/S: 06/30/2014 10:55 AM VBROWN ----  
premis number 02743138

STRUCTURE: 000 000 40X62 3BDR 2BATH SFD W DECK CRAWL

FLOOD ZONE : FLOOD ZONE X  
# BEDROOMS : 3.00 PROPOSED USE : SFD  
SEPTIC - EXISTING? : NEW TANK WATER SUPPLY : COUNTYN

PERMIT: CPSF 00 CP \* SFD

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
B101 01	6/23/14	BS	R*BLDG FOOTING / TEMP SVC POLE TIME: 17:00 VRU #: 002545457
	6/23/14	AP	T/S: June 23, 2014 10:24 AM BSUTTON Checked tpole. Need premise number
B103 01	7/08/14	DT	R*BLDG FOUND & TEMP SVC POLE TIME: 17:00 VRU #: 002551513
	7/08/14	AP	T/S: 07/07/2014 11:37 AM LSEGARS T/S: 07/08/2014 10:20 AM DETAYLOR
A814 01	7/09/14	TW	ADDRESS CONFIRMATION TIME: 17:00 VRU #: 002551851
	7/09/14	AP	T/S: 07/08/2014 08:42 AM LSEGARS 189 blairwood dr fuquay varina 27526 <del>T/S: 07/09/2014 02:37 PM TWARD</del>
B105 01	7/15/14	DT	R*OPEN FLOOR TIME: 17:00 VRU #: 002554392
	7/15/14	AP	T/S: 07/14/2014 12:09 PM DJOHNSON T/S: 07/15/2014 02:48 PM DETAYLOR
R425 01	7/31/14	KS	FOUR TRADE ROUGH IN TIME: 17:00 VRU #: 002560886
	7/31/14	AP	T/S: 07/30/2014 10:32 AM VBROWN T/S: 07/31/2014 04:15 PM KSLATTUM
I129 01	8/04/14	DT	R*INSULATION INSPECTION VRU #: 002562122
	8/04/14	AP	T/S: 08/04/2014 11:06 AM DETAYLOR
H824 01	9/02/14	JM	ENVIR. OPERATIONS PERMIT TIME: 17:00 VRU #: 002574333
	9/02/14	DA	PER JAMES MANHART OPERATIONS PERMIT FOR SEPTIC ON HOLD. NEEDS PUMP AND ALARM CHECKED BEFORE IT CAN BE ISSUED. T/S: 09/02/2014 09:53 AM SSTEWARD
E209 01	10/03/14	MR	R*ELEC TEMP POWER CERT TIME: 17:00 VRU #: 002585248
	10/03/14	AP	T/S: 10/02/2014 01:22 PM LSEGARS T/S: 10/03/2014 01:31 PM MREARIC need premise #
R429 01	10/22/14	DJ	FOUR TRADE FINAL TIME: 17:00 VRU #: 002591147
	10/21/14	CA	T/S: 10/21/2014 03:07 PM DJOHNSON NO OPERATIONS PERMIT ISSUED ON THIS HOME
H824 03	10/27/14	JM	ENVIR. OPERATIONS PERMIT TIME: 17:00 VRU #: 002593440
	10/27/14	AP	T/S: 10/28/2014 01:50 PM SSTEWARD T/S: 10/28/2014 01:51 PM SSTEWARD
H824 02	10/27/14	JM	ENVIR. OPERATIONS PERMIT TIME: 17:00 VRU #: 002593424
	10/27/14	AP	
R429 02	10/29/14	KS	FOUR TRADE FINAL TIME: 17:00 VRU #: 002593432
	10/29/14	DA	T/S: 10/29/2014 10:34 AM KSLATTUM 1. No energy certificate. 2. Need ladder to get in

PREPARED 11/04/14, 14:22:57

INSPECTION TICKET

PAGE 12

Harnett County

INSPECTOR: IVR

DATE 11/05/14

-----

ADDRESS . . : 189 BLAIRWOOD DR  
 CONTRACTOR : ROBERT CRABTREE BUILDERS INC  
 OWNER . . . : ANDERSON ENTERPRISES INC  
 PARCEL . . . : 08-0653- - -0105- -69-  
 APPL NUMBER: 14-50033308 CP NEW RESIDENTIAL (SFD)

SUBDIV: E J SMITH FARM  
 PHONE : (919) 552-5897  
 PHONE : (919) 552-3383

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
R429 03	11/05/14 <u>11-5</u>	TI <u>AP</u>	attic. 2. dryer duct length not labeled. 3. cannot have screen on dryer duct. 4. Need fall protection devices on windows 6 feet or more off the ground. 5. repair/replace broken foundation vent. FOUR TRADE FINAL TIME: 17:00 VRU #: 002595759 T/S: 11/04/2014 01:12 PM LSEGARS -----

----- COMMENTS AND NOTES -----