

COUNTY OF HARNETT
Building Inspections Department
Planning Services

Certificate of Compliance: X **Occupancy:** X

Certificate issued pursuant to the requirements of North Carolina General Statute 153A-363 and Harnett County Zoning Ordinances. This certifies at the time of issuance, this structure was in compliance with the various ordinances of the County of Harnett and the North Carolina State Building Codes. For the following:

Use Classification: R-3

Name: GML Development Inc.

Address: 82 Elgin Dr.

Date: 9-2-14

Permit Numbers

Building: 14-50033358

Electrical: "

Insulation: "

Plumbing: "

Mechanical: "

MFG Home: "

Building Official: T. M. ... (Rec'd)

 ADDRESS : 82 ELGIN DR SUBDIV: OAKMONT PH1 SC3 52LOTS
 CONTRACTOR : GML DEVELOPMENT INC PHONE : (919) 793-5237
 OWNER : OAKMONT DEV PTNRS LLC PHONE :
 PARCEL : 03-0507-01- -0046- -16-
 APPL NUMBER: 14-50033358 CP NEW RESIDENTIAL (SFD)
 DIRECTIONS : T/S: 04/07/2014 04:11 PM JBROCK ----
 OAKMONT #91

STRUCTURE: 000 000 50X55 5BDR MONO W/ GARAGE

FLOOD ZONE : FLOOD ZONE X
 # BEDROOMS : 5000000.00 PROPOSED USE : SFD
 SEPTIC - EXISTING? : NEW TANK WATER SUPPLY : COUNTY

PERMIT: CPSF 00 CP * SFD

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
B101 01	5/21/14	DT	R*BLDG FOOTING / TEMP SVC POLE VRU #: 002530517
	5/21/14	AP	T/S: 05/21/2014 01:10 PM DETAYLOR -----
B103 01	5/28/14	MR	R*BLDG FOUND & TEMP SVC POLE VRU #: 002533206
	5/28/14	AP	T/S: 05/28/2014 01:53 PM MREARIC -----
A814 01	5/29/14	CW	ADDRESS CONFIRMATION TIME: 17:00 VRU #: 002533453
	5/29/14	AP	T/S: 05/27/2014 02:33 PM DJOHNSON ----- T/S: 05/29/2014 09:59 AM CWILLIAM ----- ADDRESS FOR LOT 91 IS 82 ELGIN DR, LILLINGTON NC 27546
P309 01	6/04/14	MR	R*PLUMB UNDER SLAB VRU #: 002536878
	6/04/14	AP	T/S: 06/04/2014 12:53 PM MREARIC -----
B104 01	6/05/14	JB	R*FOUND & SETBACK VERIF SURVEY TIME: 17:00 VRU #: 002537645
	6/05/14	AP	T/S: 06/05/2014 09:25 AM JBROCK -----
B111 01	6/06/14	MR	R*BLDG SLAB INSP/TEMP SVC POLE TIME: 17:00 VRU #: 002537421
	6/06/14	AP	T/S: 06/06/2014 01:13 PM MREARIC -----
R425 01	7/10/14	MR	FOUR TRADE ROUGH IN TIME: 17:00 VRU #: 002552909
	7/10/14	DA	T/S: 07/10/2014 01:33 PM MREARIC ----- fireblock at little triangle shaped chases by mbr door / ac vent loose in 1st fl bath / fireblock at soffit by 1st fl. bath
I129 01	7/14/14	MR	R*INSULATION INSPECTION TIME: 17:00 VRU #: 002553956
	7/14/14	AP	T/S: 07/14/2014 10:57 AM MREARIC -----
R425 02	7/14/14	MR	FOUR TRADE ROUGH IN TIME: 17:00 VRU #: 002553964
	7/14/14	AP	T/S: 07/14/2014 10:57 AM MREARIC -----
H824 01	7/22/14	OT	ENVIR. OPERATIONS PERMIT TIME: 17:00 VRU #: 002560688
	7/22/14	AP	T/S: 07/29/2014 04:36 PM SSTEWARD ----- T/S: 07/29/2014 04:38 PM SSTEWARD -----
E209 01	8/21/14	FS	R*ELEC TEMP POWER CERT TIME: 17:00 VRU #: 002568301
	8/21/14	AP	T/S: 08/21/2014 01:59 PM FSPIVEY -----
R429 01	9/02/14	TI	FOUR TRADE FINAL VRU #: 002573830
	9/02/14	AP-MR	The lock box code is 7878

----- COMMENTS AND NOTES -----