

**SOIL/SITE EVALUATION
 for ON-SITE WASTEWATER SYSTEM**

Owner: Applicant: *JBW*
 Address: Date Evaluated:
 Proposed Facility: *SFD* Design Flow (.1949): *360* Property Size:
 Location of Site: Property Recorded:
 Water Supply: Public Individual Well Spring Other
 Evaluation Method: Auger Boring Pit Cut
 Type of Wastewater: Sewage Industrial Process Mixed

P R O F I L E #	.1940 Landscape Position/ Slope %	Horizon Depth (In.)	SOIL MORPHOLOGY .1941		OTHER PROFILE FACTORS				Profile Class & LTAR
			.1941 Structure/ Texture	.1941 Consistence Mineralogy	.1942 Soil Wetness/ Color	.1943 Soil Depth (IN.)	.1956 Sapro- Class	.1944 Restr Horiz	
1	<i>E</i>	0-48	<i>SL</i>	<i>fr Gr w/SP</i>					
		10-48	<i>SC-clay</i>	<i>fr 1^m SP</i>	<i>48" +</i>				<i>.4</i>
2	<i>L</i>	0-15	<i>SL</i>	<i>fr Gr w/SP</i>					
		15-48	<i>SC-clay</i>	<i>fr 1^m SP</i>	<i>42" 44" 2.5^{sp}</i>				<i>.4</i>
4.5	<i>L^R</i>	0-14	<i>SL</i>	<i>fr Gr w/SP</i>					
		14-42	<i>SC-clay</i>	<i>fr 1^m SP</i>	<i>38-40" 2.5^{sp}</i>				<i>.4</i>
6	<i>L^R</i>	0-12	<i>SL</i>	<i>fr Gr w/SP</i>					
		12-42	<i>SC-clay</i>	<i>fr 1^m SP</i>	<i>30 38 7.5^u</i>				<i>.35</i>

Description	Initial System	Repair System	Other Factors (.1946): Site Classification (.1948): <i>PS</i> Evaluated By: <i>JBW</i> Others Present:
Available Space (.1945)	<i>/</i>	<i>/</i>	
System Type(s)	<i>7.5^u</i>	<i>2.5^u</i>	
Site LTAR	<i>.4</i>	<i>.4</i>	