

COUNTY OF HARNETT
Building Inspections Department
Planning Services

Certificate of Compliance: _____

Certificate issued pursuant to the requirements of North Carolina General Statute 153A-363 and Harnett County Zoning Ordinances. This certifies at the time of issuance, this structure was in compliance with the various ordinances of the County of Harnett and the North Carolina State Building Codes. For the following:

Use Classification: Residential
Name: BRC Homes, Inc

Address: 266 English Springer Dr
Angier, NC 27501

Date: 8-6-14

Building Official: DET, O

Occupancy: X

Permit Numbers
Building: _____
Electrical: _____
Insulation: _____
Plumbing: 14-50033465
Mechanical: _____
MFG Home: _____

ADDRESS : ~~266 ENGLISH SPRINGER DR~~ SUBDIV: QUAIL GLEN PH1 32LOTS
 CONTRACTOR : BRC HOMES, INC. PHONE : (919) 422-0355
 OWNER : EMPIRE INVESTMENTS GROUP LLC PHONE :
 PARCEL : 11-0662- - -0022- -19-
 APPL NUMBER: 14-50033465 CP NEW RESIDENTIAL (SFD)

STRUCTURE: 000 000 59X70 4 BR ATT GARAGE DECK CRAWL

FLOOD ZONE : FLOOD ZONE X
 # BEDROOMS : 4.00 PROPOSED USE : SFD
 SEPTIC - EXISTING? : NEW WATER SUPPLY : COUNTY

PERMIT: CPSF 00 CP * SFD

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
B101 01	5/12/14	DT	R*BLDG FOOTING / TEMP SVC POLE TIME: 17:00 VRU #: 002526267
	5/12/14	AP	T/S: 05/12/2014 03:13 PM DETAYLOR -----
B103 01	5/15/14	BS	R*BLDG FOUND & TEMP SVC POLE TIME: 17:00 VRU #: 002528420
	5/15/14	AP	T/S: 05/14/2014 02:54 PM DJOHNSON ----- T/S: May 15, 2014 01:24 PM BSUTTON -----
A814 01	5/16/14	TW	ADDRESS CONFIRMATION TIME: 17:00 VRU #: 002528719
	5/21/14	AP	266 ENGLISH SPRINGER DR BUNNLEVEL 28323 T/S: 05/21/2014 01:20 PM TWARD -----
B105 01	5/22/14	BS	R*OPEN FLOOR TIME: 17:00 VRU #: 002530996
	5/22/14	AP	T/S: 05/21/2014 11:24 AM LSEGARS ----- T/S: May 22, 2014 02:51 PM BSUTTON -----
R425 01	6/18/14	BS	FOUR TRADE ROUGH IN TIME: 17:00 VRU #: 002543155
	6/18/14	DA	T/S: June 18, 2014 10:26 AM BSUTTON ----- Brace walls in attic supporting rafter splices. 2. Tie back rafters at least 3 ceiling joists. 3. Attic ust be floored from access to unit. 4. Repair leak at master tub drain. Ok to drop tests and retest just master tub. 5. repair electrical under house. OK TO SIDE/INSULATE
I129 01	6/23/14	BS	R*INSULATION INSPECTION TIME: 17:00 VRU #: 002545440
	6/23/14	AP	T/S: June 23, 2014 01:25 PM BSUTTON ----- Unable to verify attic access flooring. Check at final
R425 02	6/23/14	BS	FOUR TRADE ROUGH IN TIME: 17:00 VRU #: 002545432
	6/23/14	AP	T/S: June 23, 2014 01:25 PM BSUTTON ----- Unable to verify attic access flooring. Check at final
H824 01	7/10/14	JM	ENVIR. OPERATIONS PERMIT TIME: 17:00 VRU #: 002553584
	7/10/14	AP	T/S: 07/11/2014 09:57 AM SSTEWARD ----- T/S: 07/11/2014 09:57 AM SSTEWARD -----
E209 01	7/31/14	KS	R*ELEC TEMP POWER CERT TIME: 17:00 VRU #: 002561256
	7/31/14	AP	T/S: 07/30/2014 01:42 PM LSEGARS ----- T/S: 07/31/2014 04:15 PM KSLATTUM -----
R429 01	8/06/14	TI	FOUR TRADE FINAL TIME: 17:00 VRU #: 002563344
	8/6/14	AP	T/S: 08/05/2014 11:07 AM DJOHNSON -----

COMMENTS AND NOTES

ADDRESS . . : 2230 EBENEZER CHURCH RD SUBDIV: HERBERT LAWRENCE TART
CONTRACTOR : MCBRIDE HEATING & AIR CONDTN PHONE : (919) 894-8846
OWNER . . . : BEACHMAN MELINDA PHONE :
PARCEL . . . : 07-1610- - -0211- - -
APPL NUMBER: 14-50033469 CP STANDALONE TRADE - RESIDENTIAL
DIRECTIONS : T/S: 04/22/2014 01:08 PM VBROWN -----
2230 EBENEZER CHURCH RD COATS 27521

STRUCTURE: 000 000 HVAC CHG OUT EL AND MECH
FLOOD ZONE : FLOOD ZONE X
PROPOSED USE : HVAC CHG OUT WATER SUPPLY : COUNTY

PERMIT: CPER 00 CP ELECTRICAL RESIDENTIAL

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
R131 01	5/22/14 <i>5/22/14</i>	TI <i>APD</i>	ONE TRADE FINAL TIME: 17:00 VRU #: 002530947 T/S: 05/21/2014 11:03 AM VBROWN -----

PERMIT: CPMR 00 CP MECHANICAL RESIDENTIAL

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
R131 01	5/22/14 <i>5/22/14</i>	TI <i>APD</i>	ONE TRADE FINAL TIME: 17:00 VRU #: 002530954 T/S: 05/21/2014 11:04 AM VBROWN -----

----- COMMENTS AND NOTES -----