

HTE# 14-5-33480

Harnett County Department of Public Health

27926

Improvement Permit

A building permit cannot be issued with only an Improvement Permit

ISSUED TO: H+H Constructors Inc PROPERTY LOCATION: Docs Rd SUBDIVISION OAKMONT LOT # 106
NEW REPAIR EXPANSION
Type of Structure: SFO (50'x53')
Proposed Wastewater System Type: 25% REDUCTION SYSTEM
Projected Daily Flow: 600 GPD
Number of bedrooms: 5 Number of Occupants: 10 max
Basement Yes No
Pump Required: Yes No May be required based on final location and elevations of facilities
Type of Water Supply: Community Public Well Distance from well 100 feet
Permit valid for: Five years No expiration
Permit conditions: _____

Authorized State Agent: _____ Date: 4/30/14 SEE ATTACHED SITE SKETCH
The issuance of this permit by the Health Department in no way guarantees the issuance of other permits. The permit holder is responsible for checking with appropriate governing bodies in meeting their requirements. This site is subject to revocation if the site plan, plat, or the intended use changes. The Improvement Permit shall not be affected by a change in ownership of the site. This permit is subject to compliance with the provisions of the Laws and Rules for Sewage Treatment and Disposal and to conditions of this permit.

Construction Authorization

(Required for Building Permit)

The construction and installation requirements of Rules .1950, .1952, .1954, .1955, .1956, .1957, .1958, and .1959 are incorporated by references into this permit and shall be met. Systems shall be installed in accordance with the attached system layout.

ISSUED TO: H+H Constructors Inc PROPERTY LOCATION: Docs Rd SUBDIVISION OAKMONT LOT # 106
Facility Type: SFO (50'x53') New Expansion Repair
Basement? Yes No Basement Fixtures? Yes No
Type of Wastewater System** 25% REDUCTION SYSTEM (Initial) Wastewater Flow: 600 GPD
(See note below, if applicable) PANEL BLOCK (Repair)

Installation Requirements/Conditions
Septic Tank Size 1250 gallons Exact length of each trench 75 feet Trench Spacing: 9 Feet on Center
Pump Tank Size 1000 gallons Trenches shall be installed on contour at a Maximum Trench Depth of: 18-30 inches (Maximum soil cover shall not exceed 36" above the trench bottom)
Pump Requirements: _____ ft. TDH vs. _____ GPM Aggregate Depth: _____ inches below pipe _____ inches above pipe _____ inches total
Conditions: _____

WATER LINES (INCLUDING IRRIGATION) MUST BE 10FT. FROM ANY PART OF SEPTIC SYSTEM OR REPAIR AREA. NO UTILITIES ALLOWED IN INITIAL OR REPAIR DRAIN FIELD AREA.

**If applicable: I understand the system type specified is different from the type specified on the application. I accept the specifications of this permit.

Owner/Legal Representative Signature: _____ Date: _____
This Construction Authorization is subject to revocation if the site plan, plat, or the intended use changes. The Construction Authorization shall not be transferred when there is a change in ownership of the site. This Construction Authorization is subject to compliance with the provisions of the Laws and Rules for Sewage Treatment and Disposal and to the conditions of this permit. SEE ATTACHED SITE SKETCH

Authorized State Agent: _____ Date: 4/30/14
Construction Authorization Expiration Date: 4/30/19

HTE# 14-5-33480

Permit # 27926

Harnett County Department of Public Health Site Sketch

PROPERTY LOCATOR: Docs Rd

ISSUED TO: H+H CONSTRUCTION INC SUBDIVISION OAKMONT LOT # 106

Authorized State Agent: ~~RENS (OLIVER TOLKSDORF)~~ Date: 4/30/14

