Department of Environment, Health and Natural Resources
Division of Environmental Health
On-Site Wastewater Section

Sheet:
Property ID:
Lot #:
File #:
Code:

SOIL/SITE EVALUATION
for ON-SITE WASTEWATER SYSTEM

Owner: Applicant:
Address: Date Evaluated: 5/6/14
Proposed Facility: 5 bedrms Design Flow (.1949): 600 gpd Property Size:
Location of Site: Property Recorded:
Water Supply: ☒ Public ☐ Individual ☐ Well ☐ Spring ☐ Other
Evaluation Method: ☒ Auger Boring ☐ Pit ☐ Cut
Type of Wastewater: ☒ Sewage ☐ Industrial Process ☐ Mixed

PROFILE #	.1940 Landscape Position/ Slope %	Horizon Depth (In.)	SOIL MORPHOLOGY .1941		OTHER PROFILE FACTORS				Profile Class & LTAR
			.1941 Structure/ Texture	.1941 Consistence Mineralogy	.1942 Soil Wetness/ Color	.1943 Soil Depth (IN.)	.1956 Sapro Class	.1944 Restr Horiz	
1	LS 2-5	0-20	G S	VFr ns/NP					
		20-40	SBK CL*	Fr ss/sp	10YR 7/2 @ 40"				PS .45
		0-20	G S	VFr ns/NP					
		20-32	SBK SCL	Fr ss/NP					
		32-42	SBK CL*	Fr ss/sp	10YR 7/2 @ 40"				PS .45
		0-24	G S	VFr ns/NP					
		24-32	SBK SCL	Fr ss/sp					
		32-40	SBK CL	Fr ss/sp	10YR 7/2 @ 38"				PS .4

Description	Initial System	Repair System
Available Space (.1945)		
System Type(s)	~~CON (PNTR)~~	
Site LTAR	~~.5~~	~~3~~

Other Factors (.1946):
Site Classification (.1948): PS
Evaluated By: JT
Others Present: —

.45 .4 3x115 @ 18-24