

**SOIL/SITE EVALUATION
 for ON-SITE WASTEWATER SYSTEM**

Owner: Applicant:
 Address: Date Evaluated:
 Proposed Facility: L-3500 Design Flow (.1949): 480 gpd Property Size:
 Location of Site: Property Recorded:
 Water Supply: Public Individual Well Spring Other
 Evaluation Method: Auger Boring Pit Cut
 Type of Wastewater: Sewage Industrial Process Mixed


P R O F I L E #	.1940 Landscape Position/ Slope %	Horizon Depth (In.)	SOIL MORPHOLOGY .1941		OTHER PROFILE FACTORS				Profile Class & LTAR
			.1941 Structure/ Texture	.1941 Consistence Mineralogy	.1942 Soil Wetness/ Color	.1943 Soil Depth (IN.)	.1956 Sapro Class	.1944 Restr Horiz	
1		0-17	GS	VFL NS/VP					
		17-40	SBR SCL	FL SS	7.5 YR Q 30"				PS.5
2		0-16			10 YR Q 16"				
3		0-21	GS	VFL NS/VP					
		21-36	SBR SCL	FL SS	10 YR B/1 36"				PS.5
A		0-28"	GS	VFL NS/VP					S.4
B		0-16"	GS	VFL NS/VP					
		16"	U=C						
C		0-20"	GS	VFL NS/VP					
		20-26"	SBR SCL	FL SS/VP					PS.5
D		0-20"	GS	VFL NS/VP					
		20-48"	SBR SCL	FL SS/VP					PS.5

Description	Initial System	Repair System	Other Factors (.1946):
Available Space (.1945)	✓	✓	Site Classification (.1948): <u>15</u>
System Type(s)	<u>2.50% 260</u>		Evaluated By: <u>BT</u>
Site LTAR	<u>.5</u>	<u>.5</u>	Others Present: <u>BM</u>

MAP NO. 2014-150


SITE PLAN APPROVAL
DISTRICT RAZOR **USE** SFD
#BEDROOMS 4
6-2-14 clowman
ZONING ADMINISTRATOR

MAP REFERENCE: MAP NO. 2014-150



"KENTUCKY DERBY LANE" 60' R/W

MINIMUM BUILDING SET BACKS
 FRONT YARD — 30
 REAR YARD — 25
 SIDE YARD — 10
 CORNER LOT SIDE YARD — 30
 MAXIMUM HEIGHT — 35



TOWNSHIP BARBECUE		COUNTY HARNETT		20'	40'	SURVEYED BY:	FIELD BOOK
STATE: NORTH CAROLINA		DATE: MAY 21, 2014		SCALE: 1" = 40'			
ZONE RA-20R	WATERB-FD DISTRICT	TAX PARCEL ID#		CHECKED & CLOSURE BY:			14160

BENNETT SURVEYS F-1304
 1662 CLARK RD., LILLINGTON, N.C. 27546
 (910) 853-5252

PROPOSED PLOT PLAN - LOT - 29
TROTTER'S RIDGE S/D, PHASE - 3