

COUNTY OF HARNETT
Building Inspections Department
Planning Services

Certificate of Compliance: _____ **Occupancy:** X

Certificate issued pursuant to the requirements of North Carolina General Statute 153A-363 and Harnett County Zoning Ordinances. This certifies at the time of issuance, this structure was in compliance with the various ordinances of the County of Harnett and the North Carolina State Building Codes. For the following:

Use Classification: Residential

Name: Gary Robinson Home, LLC

Address: 15 Scuppernon Ln
Lillington, NC 27526

Permit Numbers

Building: _____

Electrical: _____

Insulation: _____

Plumbing: _____

Mechanical: _____

MFG Home: _____

Date: 1-6-15

Building Official: _____

DETJ

ADDRESS : 15 SCUPPERNONG LN
 CONTRACTOR : GARY ROBINSON HOMES LLC
 OWNER : JJJB INVESTMENTS, LLC
 PARCEL : 11-0651- - -0057- -55-
 APPL NUMBER: 14-50033849 CP NEW RESIDENTIAL (SFD)
 LAND NOTES : LXMN 1/14/02 SET UP PER MAP#2000/459 &459A DELETED
 11-0651-0057-05, 06, 08, 09 & 10& C/W
 11-0651-0057-04 TO CREATE TOTAL ACS
 OF 53.10. AFTER SPLITS REMAINS 26.46 AC

STRUCTURE: 000 000 54X40 4BDR 3BATH SFD W

FLOOD ZONE : FLOOD ZONE X
 # BEDROOMS : 4.00
 SEPTIC - EXISTING? : NEW SEPTIC
 PROPOSED USE : SFD
 WATER SUPPLY : COUNTY

PERMIT: CPSF 00 CP * SFD

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
B101 01	7/09/14 7/10/14	DT AP	R*BLDG FOOTING / TEMP SVC POLE TIME: 17:00 VRU #: 002551976 T/S: 07/08/2014 10:04 AM LSEGARS T/S: 07/10/2014 08:15 AM DETAYLOR
B103 01	7/25/14 7/25/14	DT AP	R*BLDG FOUND & TEMP SVC POLE VRU #: 002558757 Premise - 90768511
P309 01	7/31/14	DT	R*PLUMB UNDER SLAB VRU #: 002561082
A814 01	8/01/14 7/31/14 7/31/14	AP TW AP	T/S: 08/01/2014 11:43 AM DETAYLOR ADDRESS CONFIRMATION TIME: 17:00 VRU #: 002561058 15 scuppernong ln lillington 27546 T/S: 07/31/2014 08:41 AM TWARD
B111 01	8/06/14 8/06/14	DT AP	R*BLDG SLAB INSP/TEMP SVC POLE VRU #: 002563534 Premise Number - 90768511 T/S: 08/06/2014 02:23 PM DETAYLOR
B104 01	9/08/14 9/08/14	JB AP	R*FOUND & SETBACK VERIF SURVEY TIME: 17:00 VRU #: 002576528 T/S: 09/08/2014 02:04 PM JBROCK
R425 01	9/09/14 9/10/14	DT DA	FOUR TRADE ROUGH IN TIME: 17:00 VRU #: 002576536 T/S: 09/10/2014 07:41 AM DETAYLOR Draft stop around 2nd floor plumbing Fire block floor in front bedroom above garage Need air barrier at top plate in 3rd fl stairway Fire block top plate in pantry Okay to side and insulate
I129 01	9/12/14 9/12/14	DT AP	R*INSULATION INSPECTION TIME: 17:00 VRU #: 002577963 T/S: 09/11/2014 01:45 PM LSEGARS T/S: 09/12/2014 10:17 AM DETAYLOR
R425 02	9/12/14 9/12/14	DT AP	FOUR TRADE ROUGH IN TIME: 17:00 VRU #: 002577971 T/S: 09/11/2014 01:45 PM LSEGARS T/S: 09/12/2014 10:17 AM DETAYLOR
H824 01	9/24/14 9/24/14	JM DA	ENVIR. OPERATIONS PERMIT TIME: 17:00 VRU #: 002582310 PER JAMES MANHART OPERATIONS PERMIT ON HOLD FOR PUMP AND ALARM INSPECTION. CALL HIM 893-7547 WHEN READY. T/S: 09/24/2014 10:02 AM SSTEWARD
E209 01	10/15/14 10/15/14	TSG DA	R*ELEC TEMP POWER CERT TIME: 17:00 VRU #: 002588994 T/S: 10/14/2014 02:11 PM VBROWN inside and outside breaker panels, breakers not labeled
E209 02	10/21/14 10/21/14	DT CA	R*ELEC TEMP POWER CERT TIME: 17:00 VRU #: 002590453 T/S: 10/20/2014 01:22 PM LSEGARS

PREPARED 1/05/15, 14:25:52
Harnett County

INSPECTION TICKET
INSPECTOR: IVR

PAGE 13
DATE 1/06/15

ADDRESS : 15 SCUPPERNONG LN
CONTRACTOR : GARY ROBINSON HOMES LLC
OWNER : JJJB INVESTMENTS, LLC
PARCEL : 11-0651- - -0057- -55-
APPL NUMBER: 14-50033849 CP NEW RESIDENTIAL (SFD)

SUBDIV:
PHONE : (910) 977-2562
PHONE :

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
R125 01	10/21/14 10/21/14	DT AP	T/S: 10/21/2014 12:16 PM DETAYLOR House locked ONE TRADE ROUGH IN TIME: 17:00 VRU #: 002590461 T/S: 10/20/2014 01:22 PM LSEGARS INSPECTION ON STONE VENEER PREP T/S: 10/21/2014 12:17 PM DETAYLOR R*ELEC TEMP POWER CERT TIME: 17:00 VRU #: 002591865 T/S: 10/23/2014 11:28 AM VBROWN T/S: 10/24/2014 09:46 AM DETAYLOR ENVIR. OPERATIONS PERMIT TIME: 17:00 VRU #: 002602589 T/S: 11/24/2014 11:58 AM SSTEWARD T/S: 11/24/2014 11:58 AM SSTEWARD FOUR TRADE FINAL VRU #: 002612760 T/S: 12/30/2014 01:36 PM MREARIC a piece of insulation and air barrier is missing in attic by a/c opening FOUR TRADE FINAL TIME: 17:00 VRU #: 002614188 T/S: 01/05/2015 11:11 AM DJOHNSON LOCK BOX ON HOUSE NUMBER IS 5383
E209 03	10/24/14 10/24/14	DT AP	
H824 02	11/21/14 11/21/14	JM AP	
R429 01	12/30/14 12/30/14	MR DA	
R429 02	1/06/15 <u>1/6/15</u>	TI <u>APDT</u>	

COMMENTS AND NOTES