

**COUNTY OF HARNETT**  
**Building Inspections Department**  
**Planning Services**

**Certificate of Compliance:**   A   **Occupancy:**   X  

Certificate issued pursuant to the requirements of North Carolina General Statute 153A-363 and Harnett County Zoning Ordinances. This certifies at the time of issuance, this structure was in compliance with the various ordinances of the County of Harnett and the North Carolina State Building Codes. For the following:

Use Classification:   R-3  

Name: Wynn Construction

Address: 37 Darley Ct

Date: 8-12-16

Building Official: Michael Roarie

**Permit Numbers**

Building: 14-50033958

Electrical: \_\_\_\_\_

Insulation: \_\_\_\_\_

Plumbing: \_\_\_\_\_

Mechanical: \_\_\_\_\_

MFG Home: \_\_\_\_\_

ADDRESS : 37 DARLEY CT  
 CONTRACTOR : WYNN CONSTRUCTION, INC.  
 OWNER : WYNN CONSTRUCTION INC #46  
 PARCEL : 03-0507-01- -0200- -10-  
 APPL NUMBER: 14-50033958 CP NEW RESIDENTIAL (SFD)  
 DIRECTIONS : T/S: 06/16/2014 11:26 AM DJOHNSON --  
 TROTTERS RIDGE LOT 46  
 27W LEFT ONTO DOCS RD RIGHT INTO SUBD  
 ON KENTUCKY DERBY LN  
 PREMISE# 95626694

SUBDIV: TROTTERS RIDGE PH3 23LTS  
 PHONE : (919) 528-1347  
 PHONE :

**STRUCTURE: 000 000 60X60 4 BR ATT GARAGE PATIO CRAWL**

FLOOD ZONE : FLOOD ZONE X

# BEDROOMS : 4.00

PROPOSED USE : SFD

SEPTIC - EXISTING? : NEW

WATER SUPPLY : COUNTY

**PERMIT: CPSF 00 CP \* SFD**

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
B101 01	3/30/16	MR	R*BLDG FOOTING / TEMP SVC POLE TIME: 17:00 VRU #: 002796373
	3/30/16	AP	T/S: 03/29/2016 01:41 PM JFORBES ----- T/S: 03/30/2016 02:41 PM MREARIC -----
A814 01	4/20/16	SB	ADDRESS CONFIRMATION TIME: 17:00 VRU #: 002805208
	4/20/16	AP	37 DARLEY CT LILLINGTON 27546 T/S: 04/20/2016 09:26 AM SBENNETT -----
B103 01	4/20/16	MR	R*BLDG FOUND & TEMP SVC POLE TIME: 17:00 VRU #: 002805190
	4/20/16	DA	T/S: 04/20/2016 03:07 PM MREARIC ----- two piers are not in the right spots. no 2" projection either portal framing detail calls for bolts to footer , sealed plan
B103 02	4/21/16	MR	R*BLDG FOUND & TEMP SVC POLE TIME: 17:00 VRU #: 002806073
	4/21/16	AP	T/S: 04/20/2016 03:53 PM LBENNETT ----- T/S: 04/21/2016 01:59 PM MREARIC -----
B104 01	4/28/16	JB	R*FOUND & SETBACK VERIF SURVEY TIME: 17:00 VRU #: 002809671
	4/28/16	AP	T/S: 04/28/2016 02:18 PM JBROCK -----
B105 01	4/28/16	JH	R*OPEN FLOOR TIME: 17:00 VRU #: 002808715
	4/28/16	AP	T/S: 04/27/2016 10:53 AM JBROCK -----
R425 01	6/07/16	MR	FOUR TRADE ROUGH IN TIME: 17:00 VRU #: 002826741
	6/07/16	AP	T/S: 06/06/2016 01:56 PM JBROCK ----- T/S: 06/07/2016 01:39 PM MREARIC -----
I129 01	6/10/16	JH	R*INSULATION INSPECTION TIME: 17:00 VRU #: 002828853
	6/10/16	AP	T/S: 06/09/2016 12:39 PM JBROCK -----
R125 01	6/28/16	MR	ONE TRADE ROUGH IN TIME: 17:00 VRU #: 002837060
	6/28/16	AP	T/S: 06/27/2016 01:34 PM JBROCK ----- stone inspection T/S: 06/28/2016 03:16 PM MREARIC -----
H824 01	6/30/16	OT	ENVIR. OPERATIONS PERMIT TIME: 17:00 VRU #: 002839561
	6/30/16	AP	T/S: 07/05/2016 10:04 AM SSTEWARD ----- T/S: 07/05/2016 10:04 AM SSTEWARD ----- T/S: 07/05/2016 10:05 AM SSTEWARD -----
E209 01	8/05/16	TSG	R*ELEC TEMP POWER CERT TIME: 17:00 VRU #: 002853331
	8/05/16	AP	T/S: 08/03/2016 01:53 PM LBENNETT -----

PREPARED 8/11/16, 14:04:19  
Harnett County

INSPECTION TICKET  
INSPECTOR: IVR

PAGE 4  
DATE 8/12/16

-----  
ADDRESS . . : 37 DARLEY CT  
CONTRACTOR : WYNN CONSTRUCTION, INC.  
OWNER . . : WYNN CONSTRUCTION INC #46  
PARCEL . . : 03-0507-01- -0200- -10-  
APPL NUMBER: 14-50033958 CP NEW RESIDENTIAL (SFD)  
-----

SUBDIV: TROTTERS RIDGE PH3 23LTS  
PHONE : (919) 528-1347  
PHONE :

-----  
REQUESTED INSP DESCRIPTION  
TYP/SQ COMPLETED RESULT RESULTS/COMMENTS  
-----

R429 01 8/12/16 TI T/S: 08/03/2016 03:50 PM LBENNETT -----  
11 AP-MR FOUR TRADE FINAL TIME: 17:00 VRU #: 002856896  
T/S: 08/11/2016 01:54 PM JFORBES -----

----- COMMENTS AND NOTES -----