

Improvement Permit

A building permit cannot be issued with only an Improvement Permit

ISSUED TO: JAMES ROBERTSON PROPERTY LOCATION: DL PHILLIPS LN SUBDIVISION: JAMES ROBERTSON LOT # 8

NEW [X] REPAIR [] EXPANSION [] Site Improvements required prior to Construction Authorization Issuance:

Type of Structure: SFD (47x72) Proposed Wastewater System Type: 25% REDUCTION SYSTEM

Projected Daily Flow: 360 GPD

Number of bedrooms: 3 Number of Occupants: 6 max

Basement [] Yes [X] No

Pump Required: [] Yes [X] No [] May be required based on final location and elevations of facilities

Type of Water Supply: [] Community [X] Public [] Well Distance from well 100 feet Permit valid for: [X] Five years [] No expiration

Permit conditions:

Authorized State Agent: [Signature] REGIS Date: 7/3/14 SEE ATTACHED SITE SKETCH

The issuance of this permit by the Health Department in no way guarantees the issuance of other permits. The permit holder is responsible for checking with appropriate governing bodies in meeting their requirements. This site is subject to revocation if the site plan, plat, or the intended use changes. The Improvement Permit shall not be affected by a change in ownership of the site. This permit is subject to compliance with the provisions of the Laws and Rules for Sewage Treatment and Disposal and to conditions of this permit.

Construction Authorization

(Required for Building Permit)

The construction and installation requirements of Rules .1950, .1952, .1954, .1955, .1956, .1957, .1958, and .1959 are incorporated by references into this permit and shall be met. Systems shall be installed in accordance with the attached system layout.

ISSUED TO: JAMES ROBERTSON PROPERTY LOCATION: DL PHILLIPS LN SUBDIVISION: JAMES ROBERTSON LOT # 8

Facility Type: SFD (47x72) [X] New [] Expansion [] Repair

Basement? [] Yes [X] No Basement Fixtures? [] Yes [X] No

Type of Wastewater System** 25% REDUCTION SYSTEM (Initial) Wastewater Flow: 360 GPD

(See note below, if applicable []) 25% REDUCTION (Repair)

Installation Requirements/Conditions

Septic Tank Size 1000 gallons Number of trenches 5

Pump Tank Size gallons Exact length of each trench 80 feet Trench Spacing: 9 Feet on Center

Trenches shall be installed on contour at a Maximum Trench Depth of: 18-24 inches Soil Cover: 6-12 inches (Maximum soil cover shall not exceed 36" above the trench bottom)

(Trench bottoms shall be level to +/-1/4" in all directions)

Pump Requirements: ft. TDH vs. GPM inches below pipe

Aggregate Depth: inches above pipe

Conditions: inches total

WATER LINES (INCLUDING IRRIGATION) MUST BE 10FT. FROM ANY PART OF SEPTIC SYSTEM OR REPAIR AREA. NO UTILITIES ALLOWED IN INITIAL OR REPAIR DRAIN FIELD AREA.

**If applicable: I understand the system type specified is different from the type specified on the application. I accept the specifications of this permit.

Owner/Legal Representative Signature: Date:

This Construction Authorization is subject to revocation if the site plan, plat, or the intended use changes. The Construction Authorization shall not be transferred when there is a change in ownership of the site. This Construction Authorization is subject to compliance with the provisions of the Laws and Rules for Sewage Treatment and Disposal and to the conditions of this permit. SEE ATTACHED SITE SKETCH

Authorized State Agent: [Signature] REGIS Date: 7/3/14 Construction Authorization Expiration Date: 7/3/19


HTE# 14-5-34040

Permit # 28010

Harnett County Department of Public Health Site Sketch

ISSUED TO: JAMES ROBERTSON PROPERTY LOCATOR: DL PHILLIPS LN
SUBDIVISION: JAMES ROBERTSON LOT # 8

Authorized State Agent: ~~AGNS COLIVER TOLKSDORF~~ Date: 7/3/24



*** DO NOT
SMEAR
DITCHES!**

RAKE SIDES +
BOTTOM IF
NEEDED