

**COUNTY OF HARNETT**  
**Building Inspections Department**  
**Planning Services**

**Certificate of Compliance:**           X           **Occupancy:**           X          

Certificate issued pursuant to the requirements of North Carolina General Statute 153A-363 and Harnett County Zoning Ordinances. This certifies at the time of issuance, this structure was in compliance with the various ordinances of the County of Harnett and the North Carolina State Building Codes. For the following:

Use Classification:           R-3          

Name:           Comfort Homes Inc          

Address: \_\_\_\_\_

          86 Moonlight Dr.          

\_\_\_\_\_

Date:           11-12-14          

Building Official:           T. Michael Reavis          

**Permit Numbers**

Building:           14-50034124          

Electrical: \_\_\_\_\_

Insulation: \_\_\_\_\_

Plumbing: \_\_\_\_\_

Mechanical: \_\_\_\_\_

MFG Home: \_\_\_\_\_



ADDRESS : 106 MOONLIGHT DR SUBDIV: STETSON 53LOTS  
 CONTRACTOR : COMFORT HOMES INC PHONE : (919) 553-3242  
 OWNER : FISH BROTHERS INC PHONE :  
 PARCEL : 04-0674- - -0046- -51-  
 APPL NUMBER: 14-50034124 CP NEW RESIDENTIAL (SFD)

DIRECTIONS : T/S: 07/10/2014 03:11 PM VBROWN ----  
 106 MOONLIGHT DRIVE, STETSON SUB DIV  
 #51  
 T/S: 07/10/2014 03:23 PM VBROWN ----  
 PREMIS NUMBER 31554699

**STRUCTURE: 000 000 67X55 3BDR 2.5BATH SFD W GAR DECK CRAWL**

FLOOD ZONE : FLOOD ZONE X  
 # BEDROOMS : 3.00 PROPOSED USE : SFD  
 SEPTIC - EXISTING? : NEW TANK WATER SUPPLY : COUNTY

**PERMIT: CPSF 00 CP \* SFD**

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
B101 01	8/14/14	DT	R*BLDG FOOTING / TEMP SVC POLE VRU #: 002566958
	8/20/14	AP	T/S: 08/20/2014 02:06 PM KSLATTUM -----
B103 01	8/28/14	DT	R*BLDG FOUND & TEMP SVC POLE VRU #: 002572782
	8/28/14	AP	T/S: 08/28/2014 03:21 PM DETAYLOR -----
A814 01	8/28/14	SB	ADDRESS CONFIRMATION TIME: 17:00 VRU #: 002572774
	8/28/14	CA	T/S: 08/28/2014 11:33 AM SBENNETT ----- 106 MOONLIGHT DR FUQUAY VARINA 27526 POST # ON BOX AND HOME T/S: 08/28/2014 11:43 AM SBENNETT ----- T/S: 09/03/2014 10:33 AM TWARD -----
B105 01	9/03/14	DT	R*OPEN FLOOR VRU #: 002574155
	9/03/14	AP	T/S: 09/03/2014 01:09 PM DETAYLOR -----
A814 02	9/03/14	TW	ADDRESS CONFIRMATION TIME: 17:00 VRU #: 002574164
	9/15/14	AP	86 MOONLIGHT DR FUQUAY VARINA 27526 T/S: 09/15/2014 09:36 AM TWARD -----
I129 01	9/29/14	DT	R*INSULATION INSPECTION TIME: 17:00 VRU #: 002582831
	9/29/14	AP	T/S: 09/26/2014 09:38 AM LSEGARS ----- T/S: 09/29/2014 11:38 AM DETAYLOR -----
R425 02	9/29/14	DT	FOUR TRADE ROUGH IN TIME: 17:00 VRU #: 002582849
	9/29/14	AP	T/S: 09/26/2014 09:38 AM LSEGARS ----- T/S: 09/29/2014 11:38 AM DETAYLOR -----
M305 01	10/13/14	DT	R*PLUMB SEWER CONNECTION TIME: 17:00 VRU #: 002587822
	10/13/14	AP	T/S: 10/13/2014 12:56 PM DETAYLOR -----
P307 01	10/13/14	DT	R*PLUMB WATER CONNECTION TIME: 17:00 VRU #: 002587830
	10/13/14	AP	T/S: 10/13/2014 12:56 PM DETAYLOR -----
H824 01	10/31/14	JM	ENVIR. OPERATIONS PERMIT TIME: 17:00 VRU #: 002595668
	10/31/14	AP	T/S: 11/04/2014 11:33 AM SSTEWARD ----- T/S: 11/04/2014 11:34 AM SSTEWARD -----
R429 01	11/10/14	DT	FOUR TRADE FINAL TIME: 17:00 VRU #: 002596955
	11/10/14	DA	T/S: 11/07/2014 10:55 AM VBROWN ----- T/S: 11/10/2014 01:53 PM DETAYLOR ----- Missing breakers in panel Need insulation in crawl space
R429 02	11/12/14	TI	FOUR TRADE FINAL TIME: 17:00 VRU #: 002597631
	11	AP-MR	T/S: 11/10/2014 03:17 PM LSEGARS -----