

**SOIL/SITE EVALUATION
 for ON-SITE WASTEWATER SYSTEM**

Owner: Applicant:
 Address: Date Evaluated:
 Proposed Facility: **4 BORN** Design Flow (.1949): **490 gpd** Property Size:
 Location of Site: Property Recorded:
 Water Supply: Public Individual Well Spring Other
 Evaluation Method: Auger Boring Pit Cut
 Type of Wastewater: Sewage Industrial Process Mixed

P R O F I L E #	.1940 Landscape Position/ Slope %	Horizon Depth (In.)	SOIL MORPHOLOGY .1941		OTHER PROFILE FACTORS				Profile Class & LTAR
			.1941 Structure/ Texture	.1941 Consistence Mineralogy	.1942 Soil Wetness/ Color	.1943 Soil Depth (IN.)	.1956 Sapro Class	.1944 Restr Horiz	
		0-2	G/LS	Ufr-NMP					
		2-36	SsK/sc1	Fi-SsSP	104R7/22"				
		0-4	G/LS	Ufr-NMP					
		4-30	SsK/sc1	Fi-SsSP	104R7/24"				
		3-4	PM						
5	LS 5-7	0-48	G/LS	Ufr-NMP					S.8
6		0-48	G/LS	Ufr-NMP					S.9

Description	Initial System	Repair System	Other Factors (.1946): Site Classification (.1948): S Evaluated By: GM Others Present: Bm
Available Space (.1945)	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	
System Type(s)	PUMP 25% (20)		
Site LTAR	.8	.8	

Department of Environment, Health and Natural Resources
 Division of Environmental Health
 On-Site Wastewater Section

Sheet:
 Property ID:
 Lot #:
 File #:
 Code:

SOIL/SITE EVALUATION
for ON-SITE WASTEWATER SYSTEM

Owner: Applicant:
 Address: Date Evaluated: 10/21/12
 Proposed Facility: Design Flow (.1949): Property Size:
 Location of Site: Property Recorded:
 Water Supply: Public Individual Well Spring Other
 Evaluation Method: Auger Boring Pit Cut
 Type of Wastewater: Sewage Industrial Process Mixed

P R O F I L E #	.1940 Landscape Position/ Slope %	Horizon Depth (In.)	SOIL MORPHOLOGY .1941		OTHER PROFILE FACTORS				Profile Class & LTAR
			.1941 Structure/ Texture	.1941 Consistence Mineralogy	.1942 Soil Wetness/ Color	.1943 Soil Depth (IN.)	.1956 Sapro Class	.1944 Restr Horiz	
1	LS 5-7	0-9	G L	VF ₂ US ₁ P					
		9-27	SBK SCL	FR S/S ₂	10YR 7/2-27"				U5
		27" ¹¹	SBK CL	FR S/S ₂		STANDING WATER IN PIT			
2		0-8	G SL	VF ₂ NS/NP					
		8-18	SBK SCL	F ₀ S/S ₂ P					U5
		18" ¹²	PM		10YR 7/2-18"				

Description	Initial System	Repair System	Other Factors (.1946): Site Classification (.1948): Evaluated By: Others Present:
Available Space (.1945)			
System Type(s)			
Site LTAR			