Department of Environment, Health and Natural Resources
Division of Environmental Health
On-Site Wastewater Section

Sheet:
Property ID:
Lot #:
File #:
Code:

SOIL/SITE EVALUATION
for ON-SITE WASTEWATER SYSTEM

Owner: Applicant:
Address: Date Evaluated:
Proposed Facility: 3BQ2m Design Flow (.1949): 360gpd Property Size:
Location of Site: Property Recorded:
Water Supply: ☒ Public ☐ Individual ☐ Well ☐ Spring ☐ Other
Evaluation Method: ☒ Auger Boring ☐ Pit ☐ Cut
Type of Wastewater: ☒ Sewage ☐ Industrial Process ☐ Mixed

PROFILE #	.1940 Landscape Position/ Slope %	Horizon Depth (In.)	SOIL MORPHOLOGY .1941		OTHER PROFILE FACTORS				Profile Class & LTAR
			.1941 Structure/ Texture	.1941 Consistence Mineralogy	.1942 Soil Wetness/ Color	.1943 Soil Depth (IN.)	.1956 Sapro Class	.1944 Restr Horiz	
4,5,6	LS 0-2	0-10	GS	VFR NS/NP					
		10-18	SBK SCL	FR SS/SP					PS .425
		18-48	G SL	VFR NS/NP					
1,7		0-10	GS	VFR NS/NP					
		10-36"	SBK SCL	FR SS/SP	10YR 7/2@30"				PS .425
2,3,10		0-12	GS	VFR NS/NP					
		12"	SBK CL	FR S/SP	10YR 7/2@20"				US/PS

Description	Initial System	Repair System
Available Space (.1945)	✓	✓
System Type(s)	25% (PS)	
Site LTAR	.425	.425

Other Factors (.1946):
Site Classification (.1948): PS
Evaluated By: OX
Others Present: