

COUNTY OF HARNETT
Building Inspections Department
Planning Services

Certificate of Compliance: _____ **Occupancy:**

Certificate issued pursuant to the requirements of North Carolina General Statute 153A-363 and Harnett County Zoning Ordinances. This certifies at the time of issuance, this structure was in compliance with the various ordinances of the County of Harnett and the North Carolina State Building Codes. For the following:

Use Classification: SFD

Name: Atlantic Construction

Address: 109 Rainwater St

Date: 12-2-14

Building Official:

[Signature]

Permit Numbers

Building: _____

Electrical: _____

Insulation: 15025005-11

Plumbing: _____

Mechanical: _____

MFG Home: _____

ADDRESS : 109 RAINMAKER ST SUBDIV: SWEETWATER 71LOTS
 CONTRACTOR : ATLANTIC CONSTRUCTION PHONE : (910) 938-9053
 OWNER : DIVERSIFIELD INVESTORS INC PHONE :
 PARCEL : 01-0544- - -0004- -36-
 APPL NUMBER: 14-50034251 CP NEW RESIDENTIAL (SFD)
 DIRECTIONS : T/S: 07/22/2014 08:32 AM JBROCK ----
 SWEET WATER LOT 28

STRUCTURE: 000 000 33X39.8 3BDR SLAB W/ GARAGE

FLOOD ZONE : FLOOD ZONE X
 # BEDROOMS : 3000000.00 PROPOSED USE : SFD
 SEPTIC - EXISTING? : NEW TANK WATER SUPPLY : COUNTY

PERMIT: CPSF 00 CP * SFD

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS	TIME	VRU #
B101 01	9/04/14	JH	R*BLDG FOOTING / TEMP SVC POLE	17:00	002574986
	9/04/14	AP			
A814 01	9/10/14	TW	ADDRESS CONFIRMATION	17:00	002576908
	9/10/14	AP	109 rainmaker st linden 28356 T/S: 09/10/2014 10:41 AM TWARD		
B103 01	9/10/14	JH	R*BLDG FOUND & TEMP SVC POLE	17:00	002576890
	9/10/14	AP			
P309 01	9/16/14	JH	R*PLUMB UNDER SLAB		002578664
	9/16/14	AP			
B111 01	9/19/14	JH	R*BLDG SLAB INSP/TEMP SVC POLE	17:00	002580330
	9/19/14	AP			
B104 01	10/08/14	JB	R*FOUND & SETBACK VERIF SURVEY	17:00	002587145
	10/08/14	AP			
R425 01	10/09/14	TSG	FOUR TRADE ROUGH IN	17:00	002587160
	10/09/14	AE	1-need draft stop in hvac return chase ceiling areas several gaps.2-Verify stud count for garage triple girder truss.3-also need stud count for lvl load points in the living room.4-label dryer vent box for length.5-nail house wrap several areas in back.6-need window flange tape right side first floor. Ok to insulate.		
I129 01	10/13/14	JH	R*INSULATION INSPECTION	17:00	002587954
	10/13/14	AP			
R425 02	10/13/14	JH	FOUR TRADE ROUGH IN	17:00	002588036
	10/13/14	AP	T/S: 10/10/2014 02:21 PM DJOHNSON		
H824 01	10/14/14	BM	ENVIR. OPERATIONS PERMIT	17:00	002588705
	10/14/14	DA	PER BRYAN MCSWAIN OPERATIONS PERMIT ON HOLD FOR WATER LINE INSPECTION, CALL HIM 893-7547 TO SCHEDULE INSPECTION WHEN READY. T/S: 10/14/2014 09:19 AM SSTEWARD		
R125 01	10/21/14	JH	ONE TRADE ROUGH IN	17:00	002590297
	10/21/14	AP	WIRE FOR STONE INSPECTION		
M305 01	11/04/14	JH	R*PLUMB SEWER CONNECTION	17:00	002595304
	11/04/14	CA	PER JOHN		
P307 01	11/04/14	JH	R*PLUMB WATER CONNECTION	17:00	002595320
	11/04/14	CA	PER JOHN		
E209 01	11/13/14	JH	R*ELEC TEMP POWER CERT	17:00	002597938

ADDRESS : 109 RAINMAKER ST
CONTRACTOR : ATLANTIC CONSTRUCTION
OWNER : DIVERSIFIELD INVESTORS INC
PARCEL : 01-0544- - -0004- -36-
APPL NUMBER: 14-50034251 CP NEW RESIDENTIAL (SFD)

SUBDIV: SWEETWATER 71LOTS
PHONE : (910) 938-9053
PHONE :

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
	11/13/14	AP	T/S: 11/12/2014 08:46 AM VBROWN
M305 02	11/13/14	JH	R*PLUMB SEWER CONNECTION TIME: 17:00 VRU #: 002597912
	11/13/14	AP	./S: 11/12/2014 08:46 AM VBROWN
P307 02	11/13/14	JH	R*PLUMB WATER CONNECTION TIME: 17:00 VRU #: 002597920
	11/13/14	AP	T/S: 11/12/2014 08:46 AM VBROWN
H824 02	11/24/14	OT	ENVIR. OPERATIONS PERMIT TIME: 17:00 VRU #: 002603058
	11/24/14	AP	T/S: 11/25/2014 01:02 PM SSTEWARD
			T/S: 11/25/2014 01:03 PM SSTEWARD
R429 01	12/02/14	TI	FOUR TRADE FINAL TIME: 17:00 VRU #: 002604015
	<i>12-2-14</i>	<i>APJH</i>	

----- COMMENTS AND NOTES -----