

Harnett County Government Complex  
307 W. Cornelius Harnett Boulevard  
Lillington, NC 27546

August 15, 2014

ph: 910-893-7547  
fax: 910-893-9371

Cates Building, Inc.  
639 Executive Place, Suite 400  
Fayetteville, NC 28305

**Re: Status of Improvement Permit Application #14-5-34371 & #14-5-34372**

To Whom It May Concern,

An attempt was made to evaluate your property for the purpose of issuing an Improvement Permit. The evaluation could not be completed for one or more of the following reasons.

- 1. Use pink flags to mark property lines and irons that are set by surveyor need to be visible (*\$25.00 fee incurred*)
- 2. Use orange flags to mark house corners (*\$25.00 fee incurred*)
- 3. Directions not clear to property (*\$25.00 fee incurred*)
- 4. Property needs only brush or vegetation removed. (To be cleared by HAND)
- 5. Driveway not shown on site plan
- 6. Backhoe pits required
- 7. Other

Your application will be put on hold until the selected items above have been addressed.

When completed **please call 910-893-7547 to confirm** that the items mentioned have been corrected, we will then reschedule your property for evaluation.

Sincerely,



Bryan McSwain, R.E.H.S.  
Environmental Health OSWW Program Specialist  
Harnett County Department of Public Health

BM/sgs  
Copy: Central Permitting