


**SOIL/SITE EVALUATION
 for ON-SITE WASTEWATER SYSTEM**

Owner: _____ Applicant: Anders
 Address: _____ Date Evaluated: _____
 Proposed Facility: SPD Design Flow (.1949): 100 Property Size: _____
 Location of Site: _____ Property Recorded: _____
 Water Supply: Public Individual Well Spring Other
 Evaluation Method: Auger Boring Pit Cut
 Type of Wastewater: Sewage Industrial Process Mixed

P R O F I L E #	.1940 Landscape Position/ Slope %	Horizon Depth (In.)	SOIL MORPHOLOGY .1941		OTHER PROFILE FACTORS				Profile Class & LTAR
			.1941 Structure/ Texture	.1941 Consistence Mineralogy	.1942 Soil Wetness/ Color	.1943 Soil Depth (IN.)	.1956 Sapro Class	.1944 Restr Horiz	
1,3	L-22	0-12	SL-CLM	FRAGMENTED					
		12-40	SC-clay	VR FRAGMENTED	30-36				.3
2	L-52	0-14	SL	FRAGMENTED					
		14-42	SL-CL SC-clay	FRAGMENTED FRAGMENTED	40-42				.3
4,5	L-50/42	0-18	SL	FRAGMENTED					
		18-44	SL-CL	FRAGMENTED	40-42				.3

Description	Initial System	Repair System	Other Factors (.1946):
Available Space (.1945)			Site Classification (.1948):
System Type(s)	252	252	Evaluated By: <u>[Signature]</u>
Site LTAR	3	3	Others Present:



Section One
Mill Branch
Cabinet "C", Slide 156-A

Note:
Lots 40 through
Ballards Mill C


Laverne W. Bain, et. al.
Will Book 091E, Page 177
Deed Book 328, Page 85

Sheet One of Three
Section Three
Mill Branch

NOTE:
ALL DRAINAGE EASEMENTS SHALL BE DEDICATED
AS PUBLIC AND IT SHALL BE THE RESPONSIBILITY
OF THE PROPERTY OWNERS TO MAINTAIN THE
DRAINAGE EASEMENTS AND ANY DRAINAGE STRUCTURES
THEREIN, SO AS TO MAINTAIN THE INTEGRITY OF THE
DRAINAGE SYSTEM AND INSURE POSITIVE DRAINAGE.

1
DATE: 5-15-14
ZONING ADMINISTRATOR
SITE PLAN APPROVAL
DISTRICT BOARD USE
SED

Revisions:
01-31-06



Property Of
R and K Land Developers, L
3951 US 401 North Fuquay-Varina, NC 27526 910-892
Anderson Construction
6212 Rawls Church Road Fuquay-Varina, NC 27526

TOWNSHIP: HECTOR'S CREEK	COUNTY: H
STATE: NORTH CAROLINA	Tax ID: 08
ZONE: RA-40	PARCEL NUMBER: 0652-24-

NUMBER 2006/172-175