

**SOIL/SITE EVALUATION  
 for ON-SITE WASTEWATER SYSTEM**

Owner:                      Applicant:  
 Address:                      Date Evaluated:  
 Proposed Facility: 3 800m                      Design Flow (.1949): 360gpd  
 Location of Site:                      Property Recorded:                      Property Size:  
 Water Supply:                       Public  Individual  Well  Spring  Other  
 Evaluation Method:  Auger Boring  Pit  Cut  
 Type of Wastewater:  Sewage  Industrial Process  Mixed

P R O F I L E #	.1940 Landscape Position/ Slope %	Horizon Depth (In.)	SOIL MORPHOLOGY .1941		OTHER PROFILE FACTORS				Profile Class & LTAR
			.1941 Structure/ Texture	.1941 Consistence Mineralogy	.1942 Soil Wetness/ Color	.1943 Soil Depth (IN.)	.1956 Sapro Class	.1944 Restr Horiz	
1	Q 0-2	0-32	G S	VFA NS/NP					
		34-48	G SL	VFA NS/NP					S.6
2		0-3	G S	VFA NS/NP					
		3"	MC						VS
3		0-48	G S	VFA NS/NP					S.8
4		0-34	G S	VFA NS/NP					
		34-48	SBK SL <sup>+</sup>	FA NS/NP					S.6
5		0-34	G S	VFA NS/NP					
		34"	C SL	VFA NS/NP					S.6

Description	Initial System	Repair System	Other Factors (.1946): Site Classification (.1948): Evaluated By: [Signature] Others Present:
Available Space (.1945)	✓	✓	
System Type(s)	25' x 20'		
Site LTAR	1 C	1 G	

3x50' @ 30-10"