

COUNTY OF HARNETT
Building Inspections Department
Planning Services

Certificate of Compliance: X **Occupancy:** X
Certificate issued pursuant to the requirements of North Carolina General Statute 153A-363 and Harnett County Zoning Ordinances.
This certifies at the time of issuance, this structure was in compliance with the various ordinances of the County of Harnett and the
North Carolina State Building Codes. For the following:

Use Classification: R-3
Name: Bill Clark Homes

Address: 180 True Blue Dr.

Date: 4-20-15

Building Official: T. Michael Reavis

Permit Numbers
Building: 14-500 34573
Electrical: _____
Insulation: _____
Plumbing: _____
Mechanical: _____
MFG Home: _____

ADDRESS : 180 TRUE BLUE DR SUBDIV: PATTONS POINT
CONTRACTOR : BILL CLARK HOMES LLC PHONE : (252) 355-5805
OWNER : BILL CLARK HOMES OF FAYETTEVILLE PHONE :
PARCEL : 03-9597- - -0039- -44-
APPL NUMBER: 14-50034573 CP NEW RESIDENTIAL (SFD)
DIRECTIONS : T/S: 09/09/2014 08:33 AM JBROCK ----
PATTONS POINT #48

STRUCTURE: 000 000 40X48 3BDR SLAB W/ GARAGE & PATIO

FLOOD ZONE : FLOOD ZONE X
BEDROOMS : 3000000.00 PROPOSED USE : SFD
SEPTIC - EXISTING? : NEW TANK WATER SUPPLY : COUNTY

PERMIT: CPSF 00 CP * SFD

| TYP/SQ | REQUESTED COMPLETED | INSP RESULT | DESCRIPTION RESULTS/COMMENTS |
|---------|------------------------|----------------|--|
| B101 01 | 10/31/14 | MR | R*BLDG FOOTING / TEMP SVC POLE TIME: 17:00 VRU #: 002594612 |
| | 10/31/14 | AP | T/S: 10/30/2014 02:39 PM LSEGARS ----- T/S: 10/31/2014 02:36 PM MREARIC ----- |
| B103 01 | 11/20/14 | MR | R*BLDG FOUND & TEMP SVC POLE VRU #: 002600617 |
| | 11/20/14 | AP | T/S: 11/20/2014 12:35 PM MREARIC ----- |
| A814 01 | 11/20/14 | SB | ADDRESS CONFIRMATION TIME: 17:00 VRU #: 002600625 |
| | 11/20/14 | AP | T/S: 11/20/2014 10:12 AM SBENNETT ----- 180 TRUE BLUE DR BROADWAY 27505 POST # ON HOME T/S: 11/20/2014 10:13 AM SBENNETT ----- |
| P309 01 | 12/09/14 | MR | R*PLUMB UNDER SLAB TIME: 17:00 VRU #: 002606747 |
| | 12/09/14 | AP | T/S: 12/08/2014 02:08 PM DJOHNSON ----- T/S: 12/09/2014 01:30 PM MREARIC ----- |
| B111 01 | 12/11/14 | MR | R*BLDG SLAB INSP/TEMP SVC POLE TIME: 17:00 VRU #: 002607562 |
| | 12/11/14 | AP | T/S: 12/10/2014 12:23 PM DJOHNSON ----- T/S: 12/11/2014 01:24 PM MREARIC ----- reviewed compaction report onsite |
| R425 01 | 1/20/15 | MR | FOUR TRADE ROUGH IN TIME: 17:00 VRU #: 002617884 |
| | 1/20/15 | DA | T/S: 01/20/2015 01:26 PM MREARIC ----- bolts needed several spots / strap garage walls per code and plans / ok to side , but no insulation yet |
| R425 02 | 1/21/15 | MR | FOUR TRADE ROUGH IN TIME: 17:00 VRU #: 002619401 |
| | 1/21/15 | AP | T/S: 01/20/2015 03:25 PM VBROWN ----- T/S: 01/21/2015 02:03 PM MREARIC ----- |
| I129 01 | 1/23/15 | TSG | R*INSULATION INSPECTION TIME: 17:00 VRU #: 002620201 |
| | 1/23/15 | AP | T/S: 01/22/2015 11:56 AM DJOHNSON ----- |
| H824 01 | 2/06/15 | OT | ENVIR. OPERATIONS PERMIT TIME: 17:00 VRU #: 002625960 |
| | 2/06/15 | AP | T/S: 02/09/2015 11:11 AM SSTEWARD ----- T/S: 02/09/2015 11:12 AM SSTEWARD ----- |
| R429 01 | 4/10/15 | MR | FOUR TRADE FINAL TIME: 17:00 VRU #: 002644599 |
| | 4/10/15 | DP | T/S: 04/09/2015 09:59 AM LBENNETT ----- T/S: 04/10/2015 11:07 AM MREARIC ----- frost proof faucets // ac breaker should be 25 //deck must be braced to code |
| R429 02 | 4/15/15 | MR | FOUR TRADE FINAL TIME: 17:00 VRU #: 002646644 |
| | 4/15/15 | DA | T/S: 04/14/2015 10:08 AM DJOHNSON ----- T/S: 04/15/2015 11:49 AM MREARIC ----- porch not complete |
| R429 03 | 4/20/15 | TI | FOUR TRADE FINAL TIME: 17:00 VRU #: 002648376 |

PREPARED 4/17/15, 14:35:28
Harnett County

INSPECTION TICKET
INSPECTOR: IVR

PAGE 6
DATE 4/20/15

ADDRESS . : 180 TRUE BLUE DR
CONTRACTOR : BILL CLARK HOMES LLC
OWNER . . : BILL CLARK HOMES OF FAYETTEVILLE
PARCEL . . : 03-9597- - -0039- -44-
APPL NUMBER: 14-50034573 CP NEW RESIDENTIAL (SFD)

SUBDIV: PATTONS POINT
PHONE : (252) 355-5805
PHONE :

| TYP/SQ | REQUESTED COMPLETED | INSP RESULT | DESCRIPTION RESULTS/COMMENTS |
|--------|------------------------|----------------|---------------------------------|
|--------|------------------------|----------------|---------------------------------|

1. AP-MR T/S: 04/17/2015 10:43 AM LBENNETT -----

----- COMMENTS AND NOTES -----