

**SOIL/SITE EVALUATION
 for ON-SITE WASTEWATER SYSTEM**

Owner: Applicant:
 Address: Date Evaluated: 10/22/14
 Proposed Facility: Design Flow (.1949): Property Size:
 Location of Site: Property Recorded:
 Water Supply: Public Individual Well Spring Other
 Evaluation Method: Auger Boring Pit Cut
 Type of Wastewater: Sewage Industrial Process Mixed

P R O F I L E #	.1940 Landscape Position/ Slope %	Horizon Depth (In.)	SOIL MORPHOLOGY .1941		OTHER PROFILE FACTORS				Profile Class & LTAR
			.1941 Structure/ Texture	.1941 Consistence Mineralogy	.1942 Soil Wetness/ Color	.1943 Soil Depth (IN.)	.1956 Sapro Class	.1944 Restr Horiz	
	LS 39	0-18	G/SL	VFr NSNP					
		18-43	SBL/SC	F, SSSP	Gley 5/1 @ 0"				JS
		0-14	G/SL	VFr NSNP					
		14-27	SBL/C	F: SSP					PS 35
		27-48	G/LS	VFr NSNP					
		0-14	G/SL	VFr NSNP					
		14-26	SBL/C	F: SSP					PS 435
		26-49	G/LS	VFr NSNP					
		0-10	G/SL	VFr NSNP					
		10-30	SBL/C	F: SSSP					
		30-49	C/LS	VFr NSNP					PS 4
		0-13	G/SL	VFr NSNP					PS 4
		13-38	SBL/SC	F: SSP	10x71 @ 38"				

Description	Initial System	Repair System	Other Factors (.1946):
Available Space (.1945)			Site Classification (.1948): JS
System Type(s)	Comp 25'	25'	Evaluated By: DM
Site LTAR	.35	.35	Others Present: