



October 23, 2014

JSJ Builders, Inc.
1135 Robeson Street
Fayetteville, NC 28305

**Re: Status of Improvement Permit Application #14-5-34729, 14-5-34730, 14-5-34731, 14-5-34732
Sweet Water – Lots 9,10,15,16**

To Whom It May Concern,

An attempt was made to evaluate your property for the purpose of issuing an Improvement Permit. The evaluation could not be completed for one or more of the following reasons.

1. Use pink flags to mark all property lines and *irons* that are set by surveyor need to be visible (\$25.00 fee incurred per lot)
2. Use orange flags to mark house corners (\$25.00 fee incurred)
3. Directions not clear to property (\$25.00 fee incurred)
4. Property needs only brush or vegetation removed
5. Driveway not shown on site plan
6. Backhoe pits required
7. Other

Your application will be put on hold until the selected items above have been addressed.

When completed **please call 910-893-7547 to confirm** that the items mentioned have been corrected, we will then reschedule your property for evaluation.

Sincerely,

Bryan McSwain, R.E.H.S.
Environmental Health OSWW Program Specialist
Harnett County Department of Public Health

BM/sgs
Copy: Central Permitting