

Harfett County

INSPECTOR: IVR

DATE 6/23/15

ADDRESS : 35 SUPREME DR SUBDIV: PLTN VINEYARD GREEN
 CONTRACTOR : GARY ROBINSON HOMES LLC PHONE : (910) 977-2562
 OWNER : WMJ DEVELOPERS LLC PHONE :
 PARCEL : 11-0651- - -0057- -80-
 APPL NUMBER: 14-50034736 CP NEW RESIDENTIAL (SFD)
 DIRECTIONS : T/S: 10/09/2014 02:50 PM VBROWN ----
 35 SUPREME DRIVE, PLANTATION VINYARD
 GREEN #45

LAND NOTES : LXMN 10/05/04 SPLIT FROM THE 04 PARCEL

STRUCTURE: 000 000 44X40 3BDR 2.5BATH SFD W GAR, DECK, SLB, BN

FLOOD ZONE : FLOOD ZONE X
 # BEDROOMS : 3.00 PROPOSED USE : SFD
 SEPTIC - EXISTING? : NEW TANK WATER SUPPLY : COUNTY

PERMIT: CPSF 00 CP * SFD

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
B101 01	12/04/14	DT	R*BLDG FOOTING / TEMP SVC POLE VRU #: 002605014
	12/04/14	AP	T/S: 12/04/2014 01:08 PM DETAYLOR -----
A814 01	12/11/14	SB	ADDRESS CONFIRMATION TIME: 17:00 VRU #: 002607893
	12/11/14	AP	T/S: 12/11/2014 08:29 AM SBENNETT ----- 35 SUPREME DR LILLINGTON 27546 POST # ON HOME T/S: 12/11/2014 08:29 AM SBENNETT -----
E207 01	12/11/14	DT	R*ELEC TEMP SERVICE POLE TIME: 17:00 VRU #: 002607901
	12/11/14	AP	premise # 49909036 T/S: 12/11/2014 11:57 AM DETAYLOR -----
B103 01	12/15/14	DT	R*BLDG FOUND & TEMP SVC POLE TIME: 17:00 VRU #: 002608354
	12/16/14	AP	T/S: 12/16/2014 08:42 AM DETAYLOR -----
B105 01	12/18/14	MR	R*OPEN FLOOR TIME: 17:00 VRU #: 002610699
	12/18/14	AP	T/S: 12/18/2014 01:40 PM MREARIC -----
R425 01	1/12/15	VC	FOUR TRADE ROUGH IN TIME: 17:00 VRU #: 002616068
	1/12/15	CA	T/S: 01/09/2015 01:45 PM VBROWN ----- T/S: 01/12/2015 08:44 AM VBROWN ----- patrick called and ca insp
R425 02	1/13/15	MR	FOUR TRADE ROUGH IN TIME: 17:00 VRU #: 002616332
	1/13/15	DA	T/S: 01/13/2015 12:20 PM MREARIC ----- strap wing walls per code / finish air barriers above garage / bathroomstrap columns over three studs / install crawl space vents per code
I129 01	1/16/15	DT	R*INSULATION INSPECTION TIME: 17:00 VRU #: 002617645
	1/16/15	AP	T/S: 01/15/2015 01:58 PM VBROWN ----- T/S: 01/16/2015 01:51 PM DETAYLOR -----
R425 03	1/16/15	DT	FOUR TRADE ROUGH IN TIME: 17:00 VRU #: 002617652
	1/16/15	AP	T/S: 01/15/2015 01:58 PM VBROWN ----- T/S: 01/16/2015 01:51 PM DETAYLOR -----
E209 01	5/06/15	DT	R*ELEC TEMP POWER CERT TIME: 17:00 VRU #: 002655801
	5/06/15	AP	T/S: 05/06/2015 02:45 PM DETAYLOR ----- Need premiss #
H824 01	6/02/15	JM	ENVIR. OPERATIONS PERMIT TIME: 17:00 VRU #: 002667772
	6/02/15	AP	T/S: 06/03/2015 11:11 AM SSTEWARD ----- T/S: 06/03/2015 11:12 AM SSTEWARD -----
R429 01	6/23/15	TI	FOUR TRADE FINAL TIME: 17:00 VRU #: 002677961
			T/S: 06/22/2015 01:08 PM LBENNETT -----

11 AP-IVR

COMMENTS AND NOTES

COUNTY OF HARNETT
Building Inspections Department
Planning Services

Certificate of Compliance: X **Occupancy:** X

Certificate issued pursuant to the requirements of North Carolina General Statute 153A-363 and Harnett County Zoning Ordinances. This certifies at the time of issuance, this structure was in compliance with the various ordinances of the County of Harnett and the North Carolina State Building Codes. For the following:

Use Classification: R-3

Name: Gary Robinson Homes LLC

Address: 33 Supreme Dr

Permit Numbers

Building: 14-BCC 34736

Electrical: _____

Insulation: _____

Plumbing: _____

Mechanical: _____

MFG Home: _____

Date: 6.23.15

Building Official: M. Michael Ream