

SOIL/SITE EVALUATION
for ON-SITE WASTEWATER SYSTEM

Owner: Applicant: *Burdley*
 Address: Date Evaluated: *11-15-89-14*
 Proposed Facility: *SFD* Design Flow (.1949): *360* Property Size:
 Location of Site: Property Recorded:
 Water Supply: Public Individual Well Spring Other
 Evaluation Method: Auger Boring Pit Cut
 Type of Wastewater: Sewage Industrial Process Mixed

P R O F I L E #	.1940 Landscape Position/ Slope %	Horizon Depth (In.)	SOIL MORPHOLOGY .1941		OTHER PROFILE FACTORS				Profile Class & LTAR
			.1941 Structure/ Texture	.1941 Consistence Mineralogy	.1942 Soil Wetness/ Color	.1943 Soil Depth (IN.)	.1956 Sapro Class	.1944 Restr Horiz	
1	<i>L-18%</i>	<i>0-24</i>	<i>Rocky SL</i>	<i>no comment</i>					
		<i>24-48</i>	<i>SC-clay</i>	<i>fine grained silty</i>	<i>46-48" 7.5/2 3.1</i>				<i>.4</i>
2	<i>L-20%</i>	<i>0-24</i>	<i>SL</i>	<i>fine grained silty</i>					
		<i>24-40</i>	<i>SC-clay</i>	<i>fine grained silty</i>		<i>38-40"</i>		<i>Pr</i>	<i>.4 - .35</i>
3	<i>L-2%</i>	<i>0-28</i>	<i>SL</i>	<i>fine grained silty</i>					
		<i>28-42</i>	<i>SC-clay</i>	<i>fine grained silty</i>	<i>38-40" 7.5/2 3.1</i>				<i>.4</i>
4	<i>L-7%</i>	<i>0-38</i>	<i>SL</i>	<i>fine grained silty</i>					
		<i>38-48</i>	<i>SC-clay</i>	<i>fine grained silty</i>		<i>48" +</i>		<i>Pr</i>	<i>.4</i>

Description	Initial System	Repair System	Other Factors (.1946):
Available Space (.1945)			Site Classification (.1948):
System Type(s)	<i>250</i>	<i>240</i>	Evaluated By: <i>[Signature]</i>
Site LTAR	<i>.4-3.35</i>	<i>.4-3.35</i>	Others Present: