

**SOIL/SITE EVALUATION
 for ON-SITE WASTEWATER SYSTEM**

Owner: Applicant: Conk
 Address: Date Evaluated: 11-20-14
 Proposed Facility: SLP Design Flow (.1949):
 Location of Site: Property Recorded:
 Water Supply: Public Individual Well Spring Other
 Evaluation Method: Auger Boring Pit Cut
 Type of Wastewater: Sewage Industrial Process Mixed

P R O F I L E #	.1940 Landscape Position/ Slope %	Horizon Depth (In.)	SOIL MORPHOLOGY .1941		OTHER PROFILE FACTORS				Profile Class & LTAR
			.1941 Structure/ Texture	.1941 Consistence Mineralogy	.1942 Soil Wetness/ Color	.1943 Soil Depth (IN.)	.1956 Sapro Class	.1944 Restr Horiz	
1	<u>3-4% L</u>	<u>0-18</u>	<u>SL rocks</u>	<u>fd GL NSWP</u>					
		<u>18-40</u>	<u>SC-1A9</u>	<u>fm 1/2" S.S.P</u>	<u>36" 7.5g</u>				<u>.4</u>
2	<u>35% L</u>	<u>0-30</u>	<u>SL</u>	<u>fd CL NSWP</u>					
		<u>30-48</u>	<u>SC</u>	<u>fm 1/2" S.P</u>	<u>40" 7.5g</u>				<u>.4</u>
3	<u>35% L</u>	<u>0-24</u>	<u>SL</u>	<u>fd GL NSWP</u>					
		<u>24-48</u>	<u>SC</u>	<u>fm 1/2" S.P</u>	<u>40"</u>				<u>.4</u>
4	<u>4% L</u>	<u>0-20</u>	<u>SL</u>	<u>fd GL NSWP</u>					
		<u>20-40</u>	<u>SC</u>	<u>fm 1/2" S.P</u>	<u>36-36</u>				<u>.4</u>

Description	Initial System	Repair System	Other Factors (.1946): Site Classification (.1948): Evaluated By: <u>[Signature]</u> Others Present:
Available Space (.1945)			
System Type(s)	<u>25%</u>	<u>25%</u>	
Site LTAR	<u>.4</u>	<u>.4</u>	